

**Scope of Accreditation for the Testing Laboratory (Center)**

**Testing Center of High-voltage Equipment**

**Joint Stock Company «Research and Development Center at Federal Grid Company of Unified Energy System»**

Testing Laboratory (Testing Center) Name

**127566, Moscow, Vysokovoltny proezd, 13, buildings 1, 2, 3, 5**

**127566, Moscow, Vysokovoltny proezd, 13, building 9 (archive of Testing Center)**

Business Address

**on conformity to requirements of GOST ISO/IEC 17025-2019**

Title and requisites of interstate or national standard, which specifies general requirements to competence of testing and calibration laboratories

| No. | Documents establishing rules and techniques of research (testing) and measurements | Equipment  | OKPD 2 code | TN VED EAEU code              | Defined parameter   | Range   |
|-----|--|--|-------------|-------------------------------|---|---|
| 1   | 2  | 3  | 4           | 5                             | 6   | 7   |
| 1   | GOST 11677 Section 7 (table 23 §8, 17)   | Power transformers, transformers and transforming power electro-oven units | 27.11.4     | 8504 21<br>8504 22<br>8504 23 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br><br>- measurement of resistance | Passed / failed<br><br>1 to 300 <sup>0</sup> C<br><br>1 μΩ to 2000 Ω                |
| 2   | GOST 11677 Section 7 (table 23. §13)   | Power transformers; transformers and transforming power electro-oven units | 27.11.4     | 8504 21<br>8504 22<br>8504 23 | Short-time withstand tests and current striking shocks.<br>0,1 to 208 kV  | Irms 0,1 to 70 kA<br>Idyn 0,1 to 180 kA<br>0,1 to 4 s<br>Compliant/<br>noncompliant |
| 3   | GOST 11677 §7.1  | Power transformers   | 27.11.4     | 8504 21<br>8504 22<br>8504 23 | Perform of inspections:<br>- checking of requirements to grounding (during checking of safety requirements)                         | 1 to 500 mm<br>compliant/<br>noncompliant   |
|     |  |  |             |                               | - presence of device for slinging and horisontal movement (during checking of safety requirements)                                  | compliant/<br>noncompliant  |
|     |  |  |             |                               | - presence of devices for tank protection against internal pressure increasing (during checking of safety requirements)             | compliant/<br>noncompliant  |

| 1 | 2   | 3                  | 4       | 5                             | 6   | 7   |
|---|---|--------------------|---------|-------------------------------|---|---|
|   |   |                    |         |                               | - presence of oil level marker and valve for selection of oil sample (during checking of safety requirements)                       | compliant/<br>noncompliant  |
|   |   |                    |         |                               | - marking and presence of nameplate (during checking of safety requirements)  | compliant/<br>noncompliant  |
|   |   |                    |         |                               | - for way of protection (during checking of safety requirements)  | compliant/<br>noncompliant  |
| 4 | GOST 17544 § 6.1; 6.3                     | Power transformers | 27.11.4 | 8504 21<br>8504 22<br>8504 23 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance     | Passed / failed<br><br>1 to 300 <sup>0</sup> C<br>1 μΩ to 2000 Ω  |
| 5 | GOST R 52719 Section 10 (table 11 §8, 17) | Power transformers | 27.11.4 | 8504 21<br>8504 22<br>8504 23 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br><br>- measurement of resistance | Passed / failed<br><br>1 to 300 <sup>0</sup> C<br>1 μΩ to 2000 Ω  |
| 6 | GOST R 52719 Section 10 (table 11 §13)    |                    |         |                               | Short-time withstand tests and current striking shocks.<br>0,1 to 208 kV  | Irms 0,1 to 70 kA<br>Idyn 0,1 to 180 kA<br>Compliant/noncompliant |
| 7 | GOST R 52719 Section 10 (table 11 §14)    |                    |         |                               | Checking of sound power level (during checking of safety requirements)  | 0 to 130 dBA<br>compliant/<br>noncompliant                        |
| 8 | GOST R 52719 §10.1                        |                    |         |                               | Perform of inspections:<br>- checking of requirements to grounding (during checking of safety requirements)                         | 1 to 500 mm<br>compliant/<br>noncompliant                         |
|   |   |                    |         |                               | - presence of device for slinging and horizontal movement (during checking of safety requirements)                                  | compliant/<br>noncompliant  |
|   |   |                    |         |                               | - presence of devices for tank protection against internal pressure increasing (during checking of safety requirements)             | compliant/<br>noncompliant  |
|   |   |                    |         |                               | - presence of oil level marker and valve for selection of oil sample (during checking of safety requirements)                       | compliant/<br>noncompliant  |

| 1  | 2                                      | 3  | 4                  | 5   | 6  | 7   |
|----|--|--|--------------------|---|--|---|
|    |  |  |                    |   | - marking and presence of nameplate<br>(during checking of safety requirements)  | compliant/noncompliant                              |
|    |  |  |                    |   | - for way of protection<br>(during checking of safety requirements)  | compliant/<br>noncompliant                          |
| 9  | GOST R 52719 Section 10 (table 11 §19) |  |                    |   | - for fire safety requirements<br>(during checking of safety requirements)<br>Statistic analysis   | compliant/<br>noncompliant                          |
| 10 | GOST 12.2.024 Section 2                | Power transformers; transformers and transforming reactors   | 27.11.4<br>27.11.5 | 8504 210000<br>8504 220000<br>8504 230000 | Checking of sound power level (during checking of safety requirements)   | 0 to 130 dBA<br>compliant/<br>noncompliant          |
| 11 | GOST 12.1.004 Annex 3                  | Power transformers; transformers and transforming reactors; transformers and transforming power electro-oven units | 27.11.4<br>27.11.5 | 8504 210000<br>8504 220000<br>8504 230000 | Checking for fire safety requirements (during checking of safety requirements)<br>Statistic analysis   | compliant/<br>noncompliant                          |
| 12 | GOST 12.2.007.0 § 3.3.7                | Power transformers; transformers and transforming reactors   | 27.11.4<br>27.11.5 | 8504 210000<br>8504 220000<br>8504 230000 | Checking of resistance between grounding bolt and each accessible for touch metal non-current-carrying part (during checking of safety requirements) | 0,001 to 200 Ω<br>compliant/<br>noncompliant        |
| 13 | GOST R 55016 § 11.1; 11.3              | Power transformers   | 27.11.4            | 8504 210000<br>8504 220000<br>8504 230000 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance                      | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω |
| 14 | GOST R 51559 § 7.1                     | Power transformers   | 27.11.4            | 8504 210000<br>8504 220000<br>8504 230000 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance                      | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω |
| 15 | GOST 30830 §10.1                       | Power transformers   | 27.11.4            | 8504 210000<br>8504 220000<br>8504 230000 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance                      | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω |

| 1  | 2                       | 3   | 4                  | 5   | 6   | 7   |
|----|-------------------------|---|--------------------|---|---|---|
| 16 | GOST 12965 §6.1.2       | Power transformers  | 27.11.4            | 8504 210000<br>8504 220000<br>8504 230000 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω |
| 17 | GOST 16555 § 4.1        | Power transformers  | 27.11.4            | 8504 210000<br>8504 220000<br>8504 230000 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω |
| 18 | GOST R 54827 §23        | Power transformers  | 27.11.4            | 8504 210000<br>8504 220000<br>8504 230000 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω |
| 19 | IEC 60076-11 §10        | Power transformers  | 27.11.4            | 8504 210000<br>8504 220000<br>8504 230000 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω |
| 20 | GOST 3484.2 Section 2-6 | Power transformers, transformers and transforming reactors, transformers and transforming power electro-oven units; reactors, including current-limiting. | 27.11.4<br>27.11.5 | 8504                                      | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω |
| 21 | GOST 3484.1 Section 2   | Power transformers, transformers and transforming reactors, transformers and transforming power electro-oven units.                                       | 27.11.4            | 8504 21<br>8504 22<br>8504 23             | Checking of transformer factor  | 1 to 100<br>compliant/<br>noncompliant              |
| 22 | GOST 3484.1 Section 4   |   |                    |   | Measurement of resistance of coils to DC current  | 1 nΩ to 10 κΩ<br>Passed / failed                    |
| 23 | GOST 3484.1 Section 5   |   |                    |   | Measurement of losses and short-circuit voltage   | 0 to 12 kW<br>0 to 100 %<br>Passed / failed         |
| 24 | GOST 3484.1 Section 6   |   |                    |   | Measurement of losses and no-load current   | 0 to 12 kW<br>0 to 100 %<br>Passed / failed         |
| 25 | GOST 20243              | Power transformers, trans-  | 27.11.4            | 8504                                      | Short-time withstand tests and current striking   | Irms 0,1 to 70 kA                                   |

| 1  | 2                            | 3  | 4       | 5    | 6   | 7   |
|----|------------------------------|--|---------|------|---|---|
|    |                              | formers and transforming reactors, transformers and transforming power electro-oven units. | 27.11.5 |      | shocks.<br>0,1 to 208 kV  | Idyn 0,1 to 180 kA<br>compliant/<br>noncompliant          |
| 26 | GOST 16772 § 5.15; 5.20;     | Transformers and transforming reactors   | 27.11.4 | 8504 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω       |
| 27 | GOST 16772 § 5.1, 5.19, 5.21 |  |         |      | Checking for compliance with safety requirements  | 1 to 500 mm<br>0 to 130 dBA<br>compliant/<br>noncompliant |
| 28 | IEC 61378-1 §7.6             | Transforming transformers  | 27.11.4 | 8504 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω       |
| 29 | IEC /IEEE 60076-57-129 §9.13 | Transforming transformers  | 27.11.4 | 8504 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω       |
| 30 | GOST 20247 §6.1              | Transformers and transforming power electro-oven units                                     | 27.11.4 | 8504 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω       |
| 31 | GOST 14794 §§6.6; 6.11       | Reactors, including current-limiting reactors  | 27.11.4 | 8504 | Temperature rise tests with rated current:<br>0 to 20000 A<br>0,1 to 35 kV<br>- temperature rise<br>- measurement of resistance | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω       |
| 32 | GOST 14794 §6.12.            |  |         |      | Tests for withstand during short-circuits<br>0,1 to 12 kV   | Irms 0,1 to 40 kA<br>Idyn 0,1 to 102 kA                   |

| 1  | 2                     | 3                               | 4       | 5           | 6   | 7   |
|----|-----------------------|---------------------------------|---------|-------------|---|---|
|    |                       |                                 |         |             |   | 0,1 to 0,22 Ω<br>0,1 to 3 s<br>compliant/<br>noncompliant   |
| 33 | GOST 20248 Section 2  | Prefabricated substations (KTP) | 27.11.4 | 8537 200000 | Temperature rise tests with rated current:<br>10 to 20 000 A<br>- temperature rise<br>- measurement of resistance   | Passed / failed<br><br>1 to 300°C<br>1 μΩ to 2000 Ω   |
| 34 | GOST 20248 Section 3  |                                 |         |             | Short-time withstand tests, including for Tests for safety requirements:<br><br>- electrodynamic withstand current<br>- thermal withstand current   | Passed / failed<br><br>0,5 to 320 kA;<br>0,5 to 120 kA  |
| 35 | GOST 20248 Section 4  |                                 |         |             | Checking of external view, correctness of fulfil operating circuits, marking  | Compliant/<br>noncompliant  |
| 36 | GOST 20248 Section 7  |                                 |         |             | Tests of mechanical strength of elements of construction during multiple operations, including during Tests for safety requirements:<br>- control of mechanical characteristics and serviceability of operation mechanisms<br><br>- checking of forces during operation<br><br>- checking of blockings operation<br><br>- checking of operating equipment | Compliant/<br>noncompliant<br><br>Compliant/<br>noncompliant<br>1 to 10 000 N<br>Compliant/<br>noncompliant<br>compliant/<br>noncompliant |
| 37 | GOST 20248 Section 13 |                                 |         |             | Control assembly and mutual replacement of one-type withdrawable of apparatuses, including for Tests for safety requirements:<br>- geometrical dimensions<br>- mass<br>- checking of blockings operation  | Compliant/<br>noncompliant<br><br>1 mm to 5 000 mm<br>1 to 10 000 kg  |
| 38 | GOST 20248 Section 12 |                                 |         |             | Tests for strength during transporting<br>External, checking of serviceability  | Passed / failed   |

| 1  | 2                     | 3   | 4  | 5  | 6  | 7  |
|----|-----------------------|---|--|--|--|--|
|    |                       |   |  |  | of elements and package  | Compliant/<br>noncompliant   |
| 39 | GOST 20248 Section 14 | Prefabricated substations (KTP)   | 27.11.4                                  | 8537 200000                                  | Tests for compliance with safety requirements  | compliant/<br>noncompliant   |
| 40 | GOST 19294 §5.10      | Low power general purpose transformers for voltage to 1000 V*   | 27.11.4                                  | 8504   | Temperature rise tests with rated current:<br>- temperature rise<br>- measurement of resistance                      | Passed / failed<br>1 to 300°C<br>1 μΩ to 2000 Ω                      |
| 41 | GOST 19294 §5.12.1    |   |  |  | Measurement of Insulation resistance.  | 10 <sup>-3</sup> to 10 <sup>6</sup> Ω.<br>Compliant/<br>noncompliant |
| 42 | GOST 19294 §5.3       |   |  |  | Test of insulation with increased voltage  | 0 to 5 kV<br>compliant/<br>noncompliant                              |
| 43 | GOST 19294 §5.11      |   |  |  | Tests for withstand during short-circuits<br>0,1 to 2 kV   | 0,1 to 0,5 kA<br>compliant/<br>noncompliant                          |
| 44 | GOST 8024 Section 2   | High-voltage circuit-breakers, disconnectors and earthing switches, fault interrupters and short-circuit makers, Switchgears type of KRU and KSO, switchgears with SF <sub>6</sub> insulation (GIS), current transformers, busducts, bushing insulators | 27.12<br>27.11                           | 8535<br>8537<br>8504<br>8046                 | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- measurement of resistance         | Passed / failed<br>10 to 20 000 A<br>1 to 300°C<br>1 μΩ to 2000 Ω    |
| 45 | GOST 1516.3 § 4.14    | AC current electrical installations of 3 to 750 kV  | 27.12.1<br>27.12.2<br>27.12.3<br>27.12.4 | 8504<br>8535<br>8536<br>8537<br>8544<br>8546 | Tests of insulation of control circuits, of auxiliary circuits<br>(0 to 5 kV)  | 0 to 5 kV<br>Compliant /<br>noncompliant                             |
| 46 | GOST 1516.3 § 13.6    | Switchgears with SF <sub>6</sub> insulation (GIS) of 110 kV and higher  | 27.12.10.190                             | 8537 200000                                  | Tests of insulation of control circuits, of auxiliary circuits<br>(0 to 5 kV)  | 0 to 5 kV<br>Compliant /<br>noncompliant                             |
| 47 | GOST R 52565 §9.1     | AC current circuit-breakers for voltage 3 to 750 kV   | 27.12.10.110                             | 8535 210000<br>8535 290000                   | Tests for compliance to requirements to construction and requirements to assembling drawing, completeness, including |  |

| 1  | 2                         | 3   | 4            | 5                          | 6  | 7   |
|----|---------------------------|---|--------------|----------------------------|--|---|
|    |                           |   |              |                            | during safety checking:<br>- geometrical, mounting and connecting dimensions<br><br>- mass<br><br>- condition of protective surfaces<br><br>- condition of surface of external insulating parts<br>- correctness of filling of nameplate<br><br>- correctness of marking and branding<br><br>- compliance of mounted auxiliary equipment | 0 to 5000 mm<br>Compliant / noncompliant<br>0 to 10000 kg<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant |
| 48 | GOST R 52565 §9.2.1-9.2.3 | AC current circuit-breakers for voltage 3 to 750 kV | 27.12.10.110 | 8535 210000<br>8535 290000 | Tests for mechanical capability, including during safety checking:<br>- control of mechanical, electrical and time characteristics<br><br><br>- correct operation of device mechanisms and blockings<br>- forces   | (0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant<br>Compliant / noncompliant<br>0 to 10000 N<br>Compliant / noncompliant  |
| 49 | GOST R 52565 § 9.2.4      |   |              |                            | Tests for reliability of mechanical capability:<br>- control of mechanical, electrical and time characteristics<br><br><br>- control of serviceability of  | (0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant<br>Compliant /   |



| 1  | 2                       | 3  | 4            | 5                          | 6  | 7  |
|----|-------------------------|--|--------------|----------------------------|--|--|
|    |                         |  |              |                            | operationmechanismes<br>- control of electrical resistance   | noncompliant<br>(0 to 1000 Ω)<br>Compliant /<br>noncompliant   |
| 50 | GOST R 52565 § 9.3.5    |  |              |                            | Control of electrical strength of insula-<br>tion after switching tests and mechanical<br>wearing tests  | Compliant /<br>noncompliant  |
| 51 | GOST R 52565 §9.4       |  |              |                            | Temperature rise tests with rated current:<br><br>- current<br>- temperature rise<br>- electricalresistance<br>- own times   | Passed/ failed<br><br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 1000 Ω<br>1 to 100 ms   |
| 52 | GOST R 52565 §9.5       | AC current circuit-breakers<br>for voltage 3 to 750 kV | 27.12.10.110 | 8535 210000<br>8535 290000 | Short-time withstand tests:<br><br>- electrodynamic withstand current<br>- thermal withstand current<br>- own times<br>- force<br>- control of time characteristics  | Passed /<br>failed<br>0,1 to 320 kA<br>0,1 to 120 kA<br>1 to 100 ms<br>1 to 10 000 N<br>0 to 30 min  |
| 53 | GOST R 52565 §9.6 - 9.8 |  |              |                            | Tests for switching capability:<br>- amplitude voltage<br>(0 to 308 kV)<br>- RMS voltage<br>(0 to 220 kV)<br>- RMS value of short-circuit current<br>(0 to 63 kA)<br>- peak value of short-circuit current<br>(0 to 170 kA)<br>- control of mechanical, electrical and<br>time characteristics | Compliant / noncompliant<br>(0 to 308 kV)<br><br>(0 to 220 kV)<br><br>(0 to 63 kA)<br><br>(0 to 170 kA)<br><br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant /<br>noncompliant |
| 54 | GOST 17717 § 7.1        | High-voltage load switches                             | 27.12.10.110 | 8535 210000<br>8535 290000 | Tests for compliance to requirements to<br>construction and requirements to assem-   |  |

| 1  | 2                | 3                          | 4            | 5                          | 6   | 7   |
|----|------------------|----------------------------|--------------|----------------------------|---|---|
|    |                  |                            |              |                            | bling drawing, completeness, including during safety checking:<br>- geometrical, mounting and connecting dimensions<br><br>- mass<br><br>- condition of protection surfaces<br>- condition of surface of external insulating parts<br>- condition of surface areas for grounding bolts and presence of sign "Earth"<br>- correctness of filling of nameplate<br><br>- correctness of marking and branding | (0 to 5000 mm)<br>Compliant / noncompliant<br>(0 to 10000 kg)<br>Compliant / noncompliant<br>Compliant / noncompliant<br><br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant |
| 55 | GOST 17717 §7.3  | High-voltage load switches | 27.12.10.110 | 8535 210000<br>8535 290000 | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- own times  | Passed/ failed<br>10 to 20 kA<br>1 to 300 °C<br>1 to 100 ms   |
| 56 | GOST 17717 § 7.4 |                            |              |                            | Tests for mechanical capability and wearing tests, including during safety checking:<br>- control of mechanical, electrical and time characteristics<br><br>- control of correct operation of device mechanisms and blockings<br>- forces   | (0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant<br>Compliant / noncompliant<br>(0 to 10000 N)<br>Compliant / noncompliant                                      |
| 57 | GOST 17717 § 7.5 |                            |              |                            | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- own times   | Passed /failed<br>0,1 to 320 kA<br>0,1 to 120 kA<br>1 to 100 ms   |

| 1  | 2                   | 3   | 4            | 5                          | 6  | 7   |
|----|---------------------|---|--------------|----------------------------|--|---|
|    |                     |   |              |                            | - force<br>- control of time characteristics   | 1 to 10 000 N<br>0 to 30 мин  |
| 58 | GOST 17717 § 7.7    |   |              |                            | Tests for switching capability:<br><br>- amplitude voltage<br>- RMS voltage<br>- RMS value of short-circuit current<br>- peak value of short-circuit current<br>- control of mechanical, electrical and time characteristics | Compliant / noncompliant<br>(0 to 308 kV)<br>(0 to 220 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant |
| 59 | GOST 17717 § 7.8.1  |   |              |                            | Type tests for reliability of mechanical capability  | Passed / failed   |
| 60 | GOST 18397 §7.3     | AC current circuit-breakers for voltage 6 to 220 kV | 27.12.10.110 | 8535 210000<br>8535 290000 | Temperature rise tests with rated current:<br><br>- current<br>- temperature rise<br>- electrical resistance<br>- own times  | Passed/<br>failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω<br>1 to 100 ms   |
| 61 | GOST 18397 §7.4     |   |              |                            | Short-time withstand tests:<br><br>- electrodynamic withstand current<br>- thermal withstand current<br>- own times<br>- force<br>- control of time characteristics  | Passed / failed<br>0,1 to 320 kA<br>0,1 to 120 kA<br>1 to 100 ms<br>1 to 10 000 N<br>0 to 30 min  |
| 62 | GOST 18397 §7.5-7.7 |   |              |                            | Tests for switching capability:<br><br>- amplitude voltage<br>- RMS voltage<br>- RMS value of short-circuit current<br>- peak value of short-circuit current<br>- control of mechanical, electrical and time characteristics | Compliant / noncompliant<br>(0 to 308 kV)<br>(0 to 220 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);                             |

| 1  | 2                                | 3  | 4        | 5    | 6  | 7  |
|----|----------------------------------|--|----------|------|--|--|
|    |                                  |  |          |      |  | Compliant/<br>noncompliant   |
| 63 | GOST 18397 §7.9                  |  |          |      | <p>Tests for mechanical capability and reliability of mechanical capability:<br/>- control of mechanical, electrical and time characteristics</p> <p>- control of serviceability of operation mechanisms</p> | <p>Passed / failed<br/>(0 to 600 V);<br/>(0 to 300 A);<br/>(0 to 300 mm);<br/>(0 to 30 min);<br/>Compliant / noncompliant<br/>Compliant / noncompliant</p> |
| 64 | GOST 18397 § 7.10                |  |          |      | <p>Tests for strength during transporting.<br/>External examination of circuit-breaker package</p>   | Compliant / noncompliant   |
| 65 | IEC 62271-100 § 7.4              | High-voltage AC current circuit-breakers | 27.12.10 | 8535 | Measurement of electrical resistance   | (0 to 1000 Ω)<br>Compliant / noncompliant  |
| 66 | IEC 62271-100 § 7.5              |  |          |      | <p>Temperature rise tests with rated current:<br/>- current<br/>- temperature rise<br/>- resistance<br/>- own times</p>  | <p>Passed/ failed<br/><br/>10 to 20 000 A<br/>1 to 300 °C<br/>1 μΩ to 2000 Ω<br/>1 to 100 ms</p>   |
| 67 | IEC 62271-100 § 7.6              |  |          |      | <p>Short-time withstand tests:<br/><br/>- electrodynamic withstand current<br/>- thermal withstand current<br/>- own times<br/>- force<br/>- control of time characteristics</p>                             | <p>Passed / failed<br/><br/>0,1 to 320 kA<br/>0,1 to 120 kA<br/>1 to 100 ms<br/>1 to 10 000 N<br/>0 to 30 min</p>  |
| 68 | IEC 62271-100 § 7.101.1, 7.101.2 |  |          |      | <p>Tests for mechanical capability and wearing tests, including during safety checking:<br/>- - control of mechanical, electrical and time characteristics</p>   | <p>(0 to 600 V);<br/>(0 to 300 A);<br/>(0 to 300 mm);<br/>(0 to 30 min);</p>   |

| 1  | 2                           | 3  | 4        | 5    | 6  | 7   |
|----|-----------------------------|--|----------|------|--|---|
|    |                             |  |          |      | <ul style="list-style-type: none"> <li>- control of correct operation of device mechanisms and blockings</li> <li>- forces</li> </ul>  | Compliant / noncompliant<br>Compliant / noncompliant<br>(0 to 10000 N)<br>Compliant / noncompliant  |
| 69 | IEC 62271-100 § 7.102-7.112 |  |          |      | Tests for switching capability: <ul style="list-style-type: none"> <li>- amplitude voltage (0 to 308 kV)</li> <li>- RMS voltage (0 to 220 kV)</li> <li>- RMS value of short-circuit current (0 to 63 kA)</li> <li>- peak value of short-circuit current (0 to 170 kA)</li> <li>- control of mechanical, electrical and time characteristics</li> </ul> | Compliant / noncompliant<br>(0 to 308 kV)<br>(0 to 220 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant |
| 70 | IEC 62271-101 Sections 4-7  | High-voltage AC current circuit-breakers | 27.12.10 | 8535 | Tests for switching capability: <ul style="list-style-type: none"> <li>- amplitude voltage (0 to 308 kV)</li> <li>- RMS voltage (0 to 220 kV)</li> <li>- RMS value of short-circuit current (0 to 63 kA)</li> <li>- peak value of short-circuit current (0 to 170 kA)</li> <li>- control of mechanical, electrical and time characteristics</li> </ul> | Compliant / noncompliant<br>(0 to 308 kV)<br>(0 to 220 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant |

| 1  | 2                                | 3   | 4        | 5    | 6  | 7   |
|----|----------------------------------|---|----------|------|--|---|
| 71 | IEC 62271-103 § 7.4              | High-voltage AC current circuit-breakers for voltage above 1 kV up to 52 kV including | 27.12.10 | 8535 | Measurement of electrical resistance   | (0 to 1000 Ω)<br>Compliant / noncompliant   |
| 72 | IEC 62271-103 § 7.5              |   |          |      | Temperature rise tests with rated current:   | Passed/ failed  |
|    |                                  |   |          |      | - current<br>- temperature rise<br>- resistance<br>- own times   | 10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω<br>1 to 100 ms  |
| 73 | IEC 62271-103 § 7.6              |   |          |      | Short-time withstand tests:  | Passed / failed   |
|    |                                  |   |          |      | - electrodynamic withstand current<br>- thermal withstand current<br>- own times<br>- force<br>- control of time characteristics   | 0,1 to 320 kA<br>0,1 to 120 kA<br>1 to 100 ms<br>1 to 10 000 N<br>0 to 30 min   |
| 74 | IEC 62271-103 § 7.101            |   |          |      | Tests for switching capability:  | Compliant / noncompliant  |
|    |                                  |   |          |      | - amplitude voltage (0 to 308 kV)<br>- RMS voltage (0 to 220 kV)<br>- RMS value of short-circuit current (0 to 63 kA)<br>- peak value of short-circuit current (0 to 170 kA)<br>- control of mechanical, electrical and time characteristics | (0 to 308 kV)<br>(0 to 220 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant |
| 75 | IEC 62271-103 § 7.102.1, 7.102.2 |   |          |      | Tests for mechanical capability and wearing tests, including during safety checking:   |   |
|    |                                  |   |          |      | - control of mechanical, electrical and time characteristics   | (0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);  |

| 1  | 2                               | 3  | 4        | 5    | 6   | 7  |
|----|---------------------------------|--|----------|------|---|--|
|    |                                 |  |          |      | - control of correct operation of device mechanisms and blockings<br>- forces   | (0 to 30 min);<br>Compliant / noncompliant<br>Compliant / noncompliant<br>(0 to 10000 N)<br>Compliant / noncompliant   |
| 76 | IEC 62271-104 § 7.4             | High-voltage AC current circuit-breakers for rated voltages 52 kV and higher | 27.12.10 | 8535 | Measurement of electrical resistance  | (0 to 1000 Ω)<br>Compliant / noncompliant  |
| 77 | IEC 62271-104 § 7.5             |  |          |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance<br>- own times  | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω<br>1 to 100 ms   |
| 78 | IEC 62271-104 § 7.6             |  |          |      | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- own times<br>- force<br>- control of time characteristics   | Passed / failed<br>0,1 to 320 kA<br>0,1 to 120 kA<br>1 to 100 ms<br>1 to 10 000 N<br>0 to 30 min   |
| 79 | IEC 62271-104 § 7.101.1-7.101.3 |  |          |      | Tests for mechanical capability and wearing tests, including during safety checking:<br>- control of mechanical, electrical and time characteristics<br><br>- control of correct operation of device mechanisms and blockings<br>- forces | (0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant<br>Compliant / noncompliant<br>(0 to 10000 N)<br>Compliant / noncompliant |
| 80 | IEC 62271-104 § 7.102-7.109     |  |          |      | Tests for switching capability:<br><br>- amplitude voltage  | Compliant / noncompliant<br>(0 to 308 kV)  |

| 1  | 2                          | 3  | 4  | 5  | 6   | 7   |
|----|----------------------------|--|--|--|---|---|
|    |                            |  |  |  | (0 to 308 kV)<br>- RMS voltage<br>(0 to 220 kV)<br>- RMS value of short-circuit current<br>(0 to 63 kA)<br>- peak value of short-circuit current<br>(0 to 170 kA)<br>- control of mechanical, electrical and time characteristics | (0 to 220 kV)<br><br>(0 to 63 kA)<br><br>(0 to 170 kA)<br><br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant                                      |
| 81 | IEC TR 62271-310 section 4 | High-voltage AC current circuit-breakers for rated voltage above 52 kV | 27.12.10                                 | 8535   | Tests for switching capability:<br><br>- amplitude voltage<br>- RMS voltage<br>- RMS value of short-circuit current<br>- peak value of short-circuit current<br>- control of mechanical, electrical and time characteristics      | Compliant / noncompliant<br>(0 to 308 kV)<br>(0 to 220 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 600 V);<br>(0 to 300 A);<br><br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant |
| 82 | GOST 14254 Section 12      | Degrees of protection, provided by enclosures                          | 27.12.1<br>27.12.2<br>27.12.3<br>27.12.4 | 8504<br>8535<br>8536<br>8537<br>8546         | Degree of protection for access to dangerous parts  | (0X to 4X)<br>Compliant / noncompliant  |
| 83 | GOST 23216 §5.2.4.1        | Electrical equipment in package  | 27.12.1<br>27.12.2<br>27.12.3<br>27.12.4 | 8504<br>8535<br>8536<br>8537<br>8544<br>8546 | Tests for transporting strength:<br><br>- mass<br><br>- completeness<br><br>- external view   | Passed / failed<br>(0 to 10000 kg)<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant /   |



| 1  | 2                   | 3  | 4  | 5  | 6  | 7   |
|----|---------------------|--|--|--|--|---|
|    |                     |  |  |  |  | noncompliant  |
| 84 | GOST 9920 Section 2 | AC current electrical installations for voltage 3 to 750 kV                            | 27.12.1<br>27.12.2<br>27.12.3<br>27.12.4 | 8504<br>8535<br>8536<br>8537<br>8544<br>8546 | Relative creepage distance (calculated).<br><br>Creepage distance of external insulation   | -<br>Compliant / noncompliant (0 to 5000 mm)<br>Compliant / noncompliant  |
| 85 | GOST R 52726 § 8.1  | AC current disconnectors and earthing switches for voltage above 1 kV and their motors | 27.12.10.120                             | 8535 30                                      | Tests for compliance to requirements of construction and requirements assembling drawing, completeness, including during safety checking:<br>- geometrical, mounting and connecting dimensions<br><br>- mass<br><br>- condition of protective surfaces<br><br>- condition of surface of external insulating parts<br>- correctness of filling of nameplate<br><br>- correctness of marking and branding<br><br>- correctness of regulation<br><br>- checking of contact pressure | (1 to 5000 mm)<br>Compliant / noncompliant (0 to 10000 kg)<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant (1 to 10000 N)<br>Compliant / noncompliant |
| 86 | GOST R 52726 § 8.2  |  |  |  | Tests for mechanical capability, including during safety checking:<br>- control of mechanical, electrical and time characteristics<br><br>- correct operation of device mechanisms   | (0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant<br>Compliant /   |

| 1  | 2                                    | 3 | 4 | 5 | 6   | 7   |
|----|--------------------------------------|---|---|---|---|---|
|    |                                      |   |   |   | and blockings<br>- forces   | noncompliant<br>(0 to 10000 N)<br>Compliant /<br>Noncompliant   |
| 87 | GOST R 52726 § 8.5.1-8.5.3,<br>8.5.5 |   |   |   | Tests for reliability of mechanical capability:<br>- control of mechanical, electrical and time characteristics<br><br>- control of electrical strength of insulation<br><br>- control of electrical resistance | (0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant /<br>noncompliant<br>Compliant /<br>noncompliant<br>(0 to 1000 Ω)<br>Compliant /<br>noncompliant  |
| 88 | GOST R 52726 §8.5.4, 8.5.7,<br>8.5.8 |   |   |   | Tests for mechanical capability, including during safety checking:<br>- control of mechanical, electrical and time characteristics<br><br>- correct operation of device, mechanisms and blockings<br>- forces   | (0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant /<br>noncompliant<br>Compliant /<br>noncompliant<br>(0 to 10000 N)<br>Compliant /<br>noncompliant |
| 89 | GOST R 52726 § 8.6.2                 |   |   |   | Checking of blocking devices, including during safety checking  | Compliant /<br>noncompliant   |
| 90 | GOST R 52726 § 8.8                   |   |   |   | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance   | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω   |
| 91 | GOST R 52726 § 8.9                   |   |   |   | Short-time withstand tests:   | Passed / failed   |

| 1  | 2                         | 3                                   | 4       | 5    | 6  | 7   |
|----|---------------------------|-------------------------------------|---------|------|--|---|
|    |                           |                                     |         |      | - electrodynamic withstand current<br>- thermal withstand current<br>- own times<br>- force<br>- control of time characteristics   | 0,1 to 320 kA<br>0,1 to 120 kA<br>1 to 100 ms<br>1 to 10 000 N<br>0 to 30 min   |
| 92 | GOST R 52726 § 8.12       |                                     |         |      | Tests for strength during transporting:<br>- visualchecking of serviceability<br>ofequipment and package   | Passed /<br>failed  |
| 93 | GOST R 52726 § 8.15- 8.17 |                                     |         |      | Tests for switching capability:<br><br>- amplitude voltage<br>(0 to 308 kV)<br>- RMS voltage<br>(0 to 220 kV)<br>- RMS value of short-circuit current<br>(0 to 63 kA)<br>- peak value of short-circuit current<br>(0 to 170 kA)<br>- control of mechanical, electrical and<br>time characteristics | Compliant /<br>noncompliant<br>(0 to 308 kV)<br><br>(0 to 220 kV)<br><br>(0 to 63 kA)<br><br>(0 to 170 kA)<br><br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant /<br>noncompliant |
| 94 | GOST R 52726 § 8.19       |                                     |         |      | Checking of electrical resistanceof<br>grounding circuit<br>- resistance   | Compliant /<br>noncompliant<br>1 μΩ to 2000 Ω   |
| 95 | GOST R 52726 § 8.20, 8.21 |                                     |         |      | Tests of auxiliary contacts to short-<br>circuit current:<br>- rated (short-time) current of<br>switchingcontacts<br>(0 to 200 A)  | (0 to 200 A)<br>Passed /<br>failed  |
| 96 | GOST R 55716 § 6.4        | High-voltage switching<br>equipment | 27.12.1 | 8535 | Measurement of electrical resistance   | (0 to 1000 Ω)<br>Compliant /<br>noncompliant  |
| 97 | GOST R 55716 § 6.5        |                                     |         |      | Temperature rise tests with rated current:<br>- current  | Passed/ failed<br>10 to 20 000 A  |

| 1   | 2                    | 3   | 4       | 5    | 6  | 7   |
|-----|----------------------|---|---------|------|--|---|
|     |                      |   |         |      | - temperature rise<br>- resistance<br>- own times  | 1 to 300 °C<br>1 μΩ to 2000 Ω<br>1 to 100 ms  |
| 98  | GOST R 55716 § 6.6   |   |         |      | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- own times<br>- force   | Passed /<br>failed<br>0,1 to 320 kA<br>0,1 to 120 kA<br>1 to 100 ms<br>1 to 10 000 N  |
| 99  | IEC 62271-102 §7.4   | High-voltage AC current<br>disconnectors and earthing<br>switches | 27.12.1 | 8535 | Measurement of electrical resistance   | (0 to 1000 Ω)<br>Compliant /<br>noncompliant  |
| 100 | IEC 62271-102 §7.5   |   |         |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance  | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω   |
| 101 | IEC 62271-102 §7.6   |   |         |      | Short-time withstand tests:<br><br>- electrodynamic withstand current<br>- thermal withstand current<br>- own times<br>- force<br>- control of time characteristics  | Passed /failed<br><br>0,1 to 320 kA<br>0,1 to 120 kA<br>1 to 100 ms<br>1 to 10 000 N<br>0 to 30 min   |
| 102 | IEC 62271-102 §7.102 |   |         |      | Tests for mechanical capability and reliability of mechanical capability:<br><br>- control of mechanical, electrical and time characteristics<br><br>- control of correct operation of device mechanisms and blockings<br>- forces | (0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant /<br>noncompliant<br>Compliant /<br>noncompliant<br>(0 to 10000 N)<br>Compliant / |

| 1   | 2   | 3                               | 4            | 5   | 6   | 7   |
|-----|---|---------------------------------|--------------|---|---|---|
|     |   |                                 |              |   | - control of insulation<br>- control of electrical resistance   | noncompliant<br>Compliant /<br>noncompliant<br>(0 to 1000 Ω)  |
| 103 | IEC 62271-102 §7.101; 7.106, Annex B1; §7.107, Annex B3; §7.108, Annex B2 |                                 |              |   | Tests for switching capability:<br>- amplitude voltage<br>(0 to 308 kV)<br>- RMS voltage<br>(0 to 220 kV)<br>- RMS value of short-circuit current<br>(0 to 63 kA)<br>- peak value of short-circuit current<br>(0 to 170 kA)<br><br>- control of mechanical, electrical and time characteristics | Compliant /<br>noncompliant<br>(0 to 308 kV)<br><br>(0 to 220 kV)<br><br>(0 to 63 kA)<br><br>(0 to 170 kA)<br><br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant /<br>noncompliant |
| 104 | GOST R 52725 Section 8.18   | Non-linear surge arresters      | 27.12.10.130 | 8535 400000                               | Pressure-relief tests   | 0,1 to 80 kA<br>0,1 to 2 s<br>compliant/<br>noncompliant  |
| 105 | GOST 16357 §6.2.13  | Surge arresters with spark gaps | 27.12.10.130 | 8535 400000                               | Pressure-relief tests   | 0,1 to 40 kA<br>0,1 to 2 s<br>compliant/<br>noncompliant  |
| 106 | GOST 7746 § 9.1   | Current transformers            | 27.11.4      | 8504 310000<br>8504 320000<br>8504 330000 | Checking of external view and Checking for compliance to drawings, including for Tests for safety requirements:<br>- geometrical dimensions<br>- mass<br>- condition of protective surfaces<br>- condition of surface of external insulating parts<br>- correctness of filling of nameplate     | compliant/<br>noncompliant<br><br>1 mm to 5 000 mm<br>1 to 10 000 kg  |

| 1   | 2                 | 3 | 4 | 5 | 6  | 7   |
|-----|-------------------|---|---|---|--|---|
|     |                   |   |   |   | - correctness of marking and branding<br>- completeness<br>- checking of operating forces<br>- electrical resistance of grounding conductor  | 1 to 10 000 N<br>1 $\mu\Omega$ to 2000 $\Omega$                                   |
| 107 | GOST 7746 § 9.2.2 |   |   |   | Checking of creepage distance  | Passed / failed<br>1 to 5 000 mm  |
| 108 | GOST 7746 § 9.2.3 |   |   |   | Test of inter-turn insulation  | Passed / failed<br>0,5 to 3 kV  |
| 109 | GOST 7746 § 9.2.4 |   |   |   | Tests of electrical strength of insulation of secondary coils to 1 min power-frequency voltage, including for Tests for safety requirements: | Passed / failed<br>0,5 to 5 kV  |
| 110 | GOST 7746 § 9.2.6 |   |   |   | Test of inter-turn insulation  | Passed / failed   |
| 111 | GOST 7746 § 9.3   |   |   |   | Measurement of insulation resistance of coils  | 1 $\kappa\Omega$ to 70 G $\Omega$<br>Compliant/noncompliant                       |
| 112 | GOST 7746 § 9.6   |   |   |   | Checking of limit multiplicity (definition of full uncertainty) of secondary coils for protection:<br>- current<br>- full uncertainty        | Compliant/<br>noncompliant<br>0,1 to 120 kA<br>1 to 100 %                         |
|     |                   |   |   |   | Checking of safety factor of devices of secondary coils for measurement:<br>- current<br>- full uncertainty                                  | Compliant/<br>noncompliant<br>0,1 to 120 kA<br>1 to 100 %                         |
| 113 | GOST 7746 § 9.8   |   |   |   | Definition of magnetizing current of secondary coils   | - 0,5 to 5 kV<br>- 1 to 100 A<br>Compliant/<br>noncompliant                       |
| 114 | GOST 7746 § 9.9   |   |   |   | Temperature rise tests with rated current:<br>- current<br>- measurement of resistance<br>- temperature rise                                 | Passed / failed<br>10 to 20000 A<br>1 to 2000 $\Omega$<br>0 to 300 <sup>0</sup> C |

| 1   | 2                      | 3                    | 4       | 5  | 6  | 7  |
|-----|------------------------|----------------------|---------|--|--|--|
| 115 | GOST 7746 § 9.10       |                      |         |  | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current   | Passed /<br>failed<br>0,1 to 320 kA<br>0,1 to 120 kA   |
| 116 | GOST 7746 § 9.11       |                      |         |  | Measurement of resistance of secondary coils to DC current   | Passed / failed<br>1 $\mu\Omega$ to 2000 $\Omega$  |
| 117 | GOST 7746 § 9.17       |                      |         |  | Test of gas-filled transformers for internal arcing test   | 0,1 to 40 kA<br>0,1 to 0,5 s   |
| 118 | GOST 1983 § 9.1        | Voltage transformers | 27.11.4 | 8504 313100<br>8504 323000<br>8504 330000<br>8504 340000 | Checking for compliance to requirements assembling drawing, including for Tests for safety requirements:<br>- geometrical dimensions<br>- mass<br>- condition of protective surfaces<br>- condition of surface of external insulating parts<br>- correctness of filling of nameplate, correctness of marking and branding, completeness, checking condition of grounding | Compliant/<br>noncompliant<br><br>1 to 5000 mm<br>1 to 10 000 kg<br>compliant/<br>noncompliant<br><br>compliant/<br>noncompliant |
| 119 | GOST 1983 § 9.3        |                      |         |  | Measurement of Insulation resistance of coils  | Passed / failed<br>1 $\kappa\Omega$ to 70 $G\Omega$  |
| 120 | GOST 1983 § 9.5        |                      |         |  | Measurement of no-load current   | 1 to 100 A   |
| 121 | GOST 1983 § 9.9        |                      |         |  | Temperature rise tests with rated current:<br>- voltage to 100 kV<br>- temperature rise<br>- measurement of resistance   | Passed / failed<br>1 to 100 kV<br>1 to 300 $^{\circ}$ C<br>1 $\mu\Omega$ to 2000 $\Omega$  |
| 122 | GOST 1983 § 9.10, 9.11 |                      |         |  | Test for withstand to short-circuit current:<br><br>- voltage to 100 kV<br>- temperature rise  | Passed / failed<br><br>1 to 100 kV<br>1 to 300 $^{\circ}$ C  |
| 123 | GOST 1983 § 9.19       |                      |         |  | Checking of creepage distance  | Compliant/<br>noncompliant<br>1 to 5 000 mm  |
| 124 | GOST 1983 § 9.20       |                      |         |  | Measurement of resistance of coils to DC current   | Compliant/<br>noncompliant<br>1 $\mu\Omega$ to 2000 $\Omega$   |

| 1   | 2                         | 3   | 4                     | 5           | 6  | 7  |
|-----|---------------------------|---|-----------------------|-------------|--|--|
| 125 | GOST 1983 § 9.21          |   |                       |             | Test of gas-filled transformers for internal arcing test   | 0,1 to 40 kA<br>0,1 to 0,5 s<br>compliant/<br>noncompliant   |
| 126 | GOST 1282 § 5.5, 5.6, 5.9 | Power capacitors and capacitive installations, for increasing of power factor | 27.90.51;<br>27.90.52 | 8532        | Test of electrical strength of insulation power-frequency<br>Not above 104 kV  | Passed / failed  |
| 127 | GOST 12.2.007.5           |   | 27.90.51;<br>27.90.52 | 8532        | Checking of external view of construction:<br>- presence of grounding bolts;<br>- external view<br>- checking of Insulation resistance.<br>Above 250 V   | compliant/<br>noncompliant   |
| 128 | GOST 14694 section 3      | Switchgears type of KRU, KSO for voltage 3 to 35 kV                           | 27.12.10.190          | 8537 200000 | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- Measurement of electrical resistance  | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω  |
| 129 | GOST 14694 section 4      | Switchgears type of KRU, GIS, KSO for voltage 3 to 35 kV                      | 27.12.10.190          | 8537 200000 | Tests for mechanical strength and withstand, electromechanical tests, including during safety checking:<br>- checking of installations of accessories equipment and way of their bracing<br>- measurement of travel value and alignment of detachable contacts of main and auxiliary circuits<br>- checking of operating mechanisms of cubicle and withdrawable element<br>- checking of switching equipment of main circuit<br>- determination of characteristics of switching equipment and motors<br><br>- test of mechanical strength of elements of construction<br>- test of devices, equipment and schemes of auxiliary circuits<br>- test of blockings<br>- test of fixing devices<br>- test of earthing devices | Compliant /<br>noncompliant<br>(0 to 300 mm);<br>Compliant /<br>noncompliant<br>Passed/ failed<br><br>Compliant /<br>noncompliant<br>(0 to 30 min)<br>Compliant /<br>noncompliant<br>(0 to 10000 N)<br><br>Passed/ failed<br>Compliant / noncompliant<br>Passed/ failed<br>Passed/ failed<br>Compliant / |



| 1   | 2                     | 3  | 4            | 5           | 6   | 7   |
|-----|-----------------------|--|--------------|-------------|---|---|
|     |                       |  |              |             | - electrical insulation resistance of main and auxiliary circuits   | noncompliant<br>(0 to 50000MΩ)  |
| 130 | GOST 14694 §6.3       |  |              |             | Degree of protection for access to dangerous parts, including during safety checking  | (0X to 4X)<br>Compliant / noncompliant  |
| 131 | GOST 14694 section 7  | Switchgears type of KRU, KSO for voltage 3 to 35 kV      | 27.12.10.190 | 8537 200000 | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- control of mechanical and time characteristics  | Passed /failed<br>0,1 to 320 kA<br>0,1 to 120 kA<br>(0 to 30 min);<br>Compliant / noncompliant  |
| 132 | GOST 14694 section 8  | Switchgears type of KRU, GIS, KSO for voltage 3 to 35 kV | 27.12.10.190 | 8537 200000 | Tests for strength during transporting:<br><br>- mass<br><br>- checking of construction and operating mechanisms<br>- checking of completeness<br><br>- checking of package                                     | Passed / failed<br>(0 to 10000 kg)<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant  |
| 133 | GOST 14694 section 9  | Switchgears type of KRU, KSO for voltage 3 to 35 kV      | 27.12.10.190 | 8537 200000 | Tests for switching capability:<br><br>- amplitude voltage<br>- RMS voltage<br>- short-circuit current<br>- peak value of short-circuit current<br>- control of mechanical, electrical and time characteristics | Compliant / noncompliant<br>(0 to 80 kV)<br>(0 to 40,5 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant |
| 134 | GOST 14694 section 10 | Switchgears type of KRU, GIS, KSO for voltage 3 to       | 27.12.10.190 | 8537 200000 | Control of assembly, Tests for mutual replacement of one-   |   |

| 1   | 2                                | 3  | 4                   | 5           | 6   | 7   |
|-----|----------------------------------|--|---------------------|-------------|---|---|
|     |                                  | 35 kV  |                     |             | typewithdrawableelements and external view, including during safety checking:<br>- external examination and compliance to assembling drawings;<br><br>- checking of operating mechanisms of cubicle and withdrawable element<br>- test of blockings<br>- forces for handling of moving mechanism<br><br>- checking of electrical strength of insulation of maincircuits toshort-timeACvoltage | (0 to 5000 mm)<br>Compliant / noncompliant<br>Compliant / noncompliant<br>Passed / failed<br>(0 to 10000 N)<br>Compliant / noncompliant<br>Passed / failed                                    |
| 135 | GOST 14694 section 12            | Switchgears type of KRU, GIS, KSO, KTPfor voltage 3 to 35 kV | 27.11.4<br>27.12.10 | 8537        | Tests for localizationcapability:<br><br>- highest servicevoltage<br>- short-circuit current<br>- peak value of short-circuit current<br>- control of time characteristics  | Compliant / noncompliant<br>(0 to 40,5 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 30 min)  |
| 136 | GOST 14694 section 13            | Switchgears type of KRU, GIS, KSO for voltage 3 to 35 kV     | 27.12.10.190        | 8537 200000 | Tests for switching capability during no-load current of transformer for own needs:<br>- amplitude voltage<br>- RMS voltage<br>- short-circuit current<br>- peak value of short-circuit current<br>- control of mechanical, electrical and time characteristics   | Compliant / noncompliant<br>(0 to 80 kV)<br>(0 to 40,5 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant / noncompliant |
| 137 | GOST 14693 § 5.4                 | Switchgears type of KRU, GIS, KSO for voltage 3 to 35 kV     | 27.12.10.190        | 8537 200000 | During Test of electrical strength of insulation of auxiliary circuits, including during safety checking  | (0 to 5 kV)<br>Passed/ failed   |
| 138 | GOST R 55190 § 5.2, 5.3.2-5.3.4, | Switchgears type of KRU,                                     | 27.12.10.190        | 8537 200000 | Checking for compliance of construction   |   |

| 1   | 2                     | 3                          | 4 | 5 | 6   | 7  |
|-----|-----------------------|----------------------------|---|---|---|--|
|     | 5.10, 5.12, 5.21-5.23 | GIS for voltage 3 to 35 kV |   |   | and assembling drawing, including for<br>Tests for safety requirements<br>- presence of grounding<br><br>- geometrical dimensions, mounting and<br>connecting<br><br>- correctness of filling of nameplate<br>and correctness of marking<br>- external view<br><br>- mass | Compliant /<br>noncompliant<br>(0 to 5000 mm)<br>Compliant /<br>noncompliant<br>Compliant /<br>noncompliant<br>Compliant /<br>noncompliant<br>(0 to 10000 kg)<br>Compliant /<br>noncompliant |
| 139 | GOST R 55190 § 5.11   |                            |   |   | Checkingblockings devices, including<br>for Tests for safety requirements   | Compliant /<br>noncompliant  |
| 140 | GOST R 55190 § 6.3    |                            |   |   | Measurement of electrical resistance  | (0 to 1000 Ω)<br>Compliant /<br>noncompliant   |
| 141 | GOST R 55190 § 6.4    |                            |   |   | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance   | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω  |
| 142 | GOST R 55190 § 6.5    |                            |   |   | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- own times<br>- control of time characteristics  | Passed / failed<br>0,1 to 320 kA<br>0,1 to 120 kA<br>1 to 100 ms<br>0 to 30 min  |
| 143 | GOST R 55190 § 6.6    |                            |   |   | Degree of protection for access to dan-<br>gerous parts, including during safety<br>checking.   | (0Xto 4X)<br>Compliant /<br>noncompliant   |
| 144 | GOST R 55190 § 6.11   |                            |   |   | Tests for switching capability:<br><br>- amplitude voltage<br>- RMS voltage<br>- short-circuit current<br>- peak value of short-circuit current<br>- control of mechanical, electrical and  | Compliant /<br>noncompliant<br>(0 to 80 kV)<br>(0 to 40,5 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 600 V);  |

| 1   | 2                               | 3  | 4            | 5           | 6   | 7   |
|-----|---------------------------------|--|--------------|-------------|---|---|
|     |                                 |  |              |             | time characteristics  | (0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant /<br>noncompliant                  |
| 145 | GOST R 55190 § 6.12             |  |              |             | Mechanical tests (electromechanical tests), including during safety checking:<br><br>- checking of operating mechanisms of cubicle and withdrawable element<br>- checking of switching equipment of main circuit<br>- test of blockings | Compliant /<br>noncompliant<br>Compliant /<br>noncompliant<br>Compliant /<br>noncompliant         |
| 146 | GOST R 55190 § 6.17,<br>Annex A |  |              |             | Tests for exposure of electric arc (localization capability):<br>- highest service voltage<br>- short-circuit current<br>- peak value of short-circuit current<br>- control of time characteristics                                     | Compliant /<br>noncompliant<br>(0 to 40,5 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 30 min)   |
| 147 | IEC 62271-200 § 7.4             | AC current metal-enclosed switchgears for rated voltage 1 to 52 kV | 27.12.10.190 | 8537 200000 | Measurement of electrical resistance  | (0 to 1000 Ω)<br>Compliant /<br>noncompliant  |
| 148 | IEC 62271-200 § 7.5             |  |              |             | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance   | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω                                 |
| 149 | IEC 62271-200 § 7.6             |  |              |             | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- control of mechanical and time characteristics  | Passed /failed<br>0,1 to 320 kA<br>0,1 to 120 kA<br>(0 to 30 min);<br>Compliant /<br>noncompliant |
| 150 | IEC 62271-200 § 7.101           |  |              |             | Tests for switching capability:   | Compliant /<br>noncompliant   |

| 1   | 2                              | 3   | 4            | 5           | 6  | 7   |
|-----|--------------------------------|---|--------------|-------------|--|---|
|     |                                |   |              |             | <ul style="list-style-type: none"> <li>- amplitude voltage</li> <li>- RMS voltage</li> <li>- short-circuit current</li> <li>- peak value of short-circuit current</li> <br/> <li>- control of mechanical, electrical and time characteristics</li> </ul>             | <ul style="list-style-type: none"> <li>(0 to 80 kV)</li> <li>(0 to 40,5 kV)</li> <li>(0 to 63 kA)</li> <li>(0 to 170 kA)</li> <br/> <li>(0 to 600 V);</li> <li>(0 to 300 A);</li> <li>(0 to 300 mm);</li> <li>(0 to 30 min);</li> <li>Compliant / noncompliant</li> </ul> |
| 151 | IEC 62271-200 § 7.102          |   |              |             | Mechanical tests<br>(electromechanical tests): <ul style="list-style-type: none"> <li>- checking of operating of cubicle mechanisms and withdrawable element</li> <li>- checking of switching of main circuit equipment</li> <li>- test of blockings</li> </ul>      | <ul style="list-style-type: none"> <li>Compliant / noncompliant</li> <li>Compliant / noncompliant</li> <li>Compliant / noncompliant</li> </ul>  |
| 152 | IEC 62271-200 § 7.106, Annex A |   |              |             | Tests for exposure of electric arc (localization capability): <ul style="list-style-type: none"> <li>- highest service voltage</li> <li>- short-circuit current</li> <li>- peak value of short-circuit current</li> <li>- control of time characteristics</li> </ul> | <ul style="list-style-type: none"> <li>Compliant / noncompliant</li> <li>(0 to 40,5 kV)</li> <li>(0 to 63 kA)</li> <li>(0 to 170 kA)</li> <li>(0 to 30 min)</li> </ul>  |
| 153 | IEC 62271-201 § 6.4            | AC current switchgears with solid insulation for rated voltage 1 to 52 kV | 27.12.10.190 | 8537 200000 | Measurement of electrical resistance   | <ul style="list-style-type: none"> <li>(0 to 1000 Ω)</li> <li>Compliant / noncompliant</li> </ul>   |
| 154 | IEC 62271-201 § 6.5            |   |              |             | Temperature rise tests with rated current: <ul style="list-style-type: none"> <li>- current</li> <li>- temperature rise</li> <li>- resistance</li> </ul>   | <ul style="list-style-type: none"> <li>Passed/ failed</li> <li>10 to 20 000 A</li> <li>1 to 300 °C</li> <li>1 μΩ to 2000 Ω</li> </ul>   |
| 155 | IEC 62271-201 § 6.6            |   |              |             | Short-time withstand tests: <ul style="list-style-type: none"> <li>- electrodynamic withstand current</li> <li>- thermal withstand current</li> </ul>  | <ul style="list-style-type: none"> <li>Passed / failed</li> <li>0,1 to 320 kA</li> <li>0,1 to 120 kA</li> </ul>   |
|     |                                |   |              |             |  |   |

| 1   | 2  | 3   | 4            | 5           | 6   | 7   |
|-----|--|---|--------------|-------------|---|---|
|     |  |   |              |             | - control of mechanical and time characteristics  | (0 to 30 min);<br>Compliant /<br>noncompliant   |
| 156 | IEC 62271-201 § 6.101                          |   |              |             | Tests for switching capability:<br><br>- amplitude voltage<br>- RMS voltage<br>- short-circuit current<br>- peak value of short-circuit current<br>- control of mechanical, electrical and time characteristics                               | Compliant /<br>noncompliant<br>(0 to 80 kV)<br>(0 to 40,5 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant /<br>noncompliant |
| 157 | IEC 62271-201 § 6.102                          |   |              |             | Mechanical tests<br>(electromechanical tests):<br>- checking of operating mechanisms cubicle and withdrawable element<br>- checking of switching of main circuit equipment<br>- test of blockings   | Compliant /<br>noncompliant<br>Compliant /<br>noncompliant<br>Compliant /<br>noncompliant   |
| 158 | IEC 62271-201 § 6.105, Annex AA                |   |              |             | Tests for exposure of electric arc (localization capability):<br>- highest service voltage<br>- short-circuit current<br>- peak value of short-circuit current<br>- control of time characteristics   | Compliant /<br>noncompliant<br>(0 to 40,5 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 30 min)   |
| 159 | GOST R 54828 §5.1-5.3, 5.9-5.11, 5.12.1, 6.1.2 | Metal-enclosed switchgears with SF <sub>6</sub> insulation (GIS) for rated voltages 110 kV and higher | 27.12.10.190 | 8537 200000 | Checking for compliance of construction and assembling drawing, including for Tests for safety requirements:<br>- presence of grounding<br><br>- geometrical dimensions, mounting and connecting<br><br>- correctness of filling of nameplate | Compliant /<br>noncompliant<br>(0 to 5000 mm)<br>Compliant /<br>noncompliant<br>Compliant /   |

| 1   | 2                    | 3 | 4 | 5 | 6  | 7   |
|-----|----------------------|---|---|---|--|---|
|     |                      |   |   |   | <ul style="list-style-type: none"> <li>incorrectness of marking</li> <li>- external view</li> <li>- mass</li> </ul>  | <ul style="list-style-type: none"> <li>noncompliant</li> <li>Compliant / noncompliant</li> <li>(0 to 10000 kg)</li> <li>Compliant / noncompliant</li> </ul>   |
| 160 | GOST R 54828 §6.4    |   |   |   | Measurement of electrical resistance   | <ul style="list-style-type: none"> <li>(0 to 1000 Ω)</li> <li>Compliant / noncompliant</li> </ul>   |
| 161 | GOST R 54828 §6.5    |   |   |   | <ul style="list-style-type: none"> <li>Temperature rise tests with rated current:</li> <li>- current</li> <li>- temperature rise</li> <li>- resistance</li> <li>- own times</li> </ul>   | <ul style="list-style-type: none"> <li>Passed/ failed</li> <li>10 to 20 000 A</li> <li>1 to 300 °C</li> <li>1 μΩ to 2000 Ω</li> <li>1 to 100 ms</li> </ul>  |
| 162 | GOST R 54828 §6.6    |   |   |   | <ul style="list-style-type: none"> <li>Short-time withstand tests:</li> <li>- electrodynamic withstand current</li> <li>- thermal withstand current</li> <li>- control of time characteristics</li> </ul>  | <ul style="list-style-type: none"> <li>Passed /failed</li> <li>0,1 to 320 kA</li> <li>0,1 to 120 kA</li> <li>0 to 30 min</li> </ul>   |
| 163 | GOST R 54828 §6.12   |   |   |   | <ul style="list-style-type: none"> <li>Tests for switching capability:</li> <li>- amplitude voltage</li> <li>- RMS voltage</li> <li>- RMS value of short-circuit current</li> <li>- peak value of short-circuit current</li> <li>- control of mechanical, electrical and time characteristics</li> </ul> | <ul style="list-style-type: none"> <li>Compliant / noncompliant</li> <li>(0 to 308 kV)</li> <li>(0 to 220 kV)</li> <li>(0 to 63 kA)</li> <li>(0 to 170 kA)</li> <li>(0 to 600 V);</li> <li>(0 to 300 A);</li> <li>(0 to 300 mm);</li> <li>(0 to 30 min);</li> <li>Compliant / noncompliant</li> </ul> |
| 164 | GOST R 54828 §6.13.1 |   |   |   | <ul style="list-style-type: none"> <li>Mechanical tests (electromechanical tests), including during safety checking:</li> <li>- checking of operating mechanisms cubicle and withdrawable element</li> <li>- checking of switching of main circuit</li> </ul>  | <ul style="list-style-type: none"> <li>Compliant / noncompliant</li> <li>Compliant / noncompliant</li> </ul>  |

| 1   | 2                          | 3   | 4            | 5           | 6   | 7   |
|-----|----------------------------|---|--------------|-------------|---|---|
|     |                            |   |              |             | equipment<br>- test of blockings  | Compliant /<br>noncompliant   |
| 165 | GOST R 54828 §6.16, AnnexG |   |              |             | Tests for exposure of electric arc<br>(localization capability):<br>- highest service voltage<br>- short-circuit current<br>- peak value of short-circuit current<br>- control of time characteristics                          | Compliant /<br>noncompliant<br>(0 to 40,5 kV)<br>(0 to 50 kA)<br>(0 to 135 kA)<br>(0 to 30 min)   |
| 166 | IEC 62271-203 §7.4         | Metal-enclosed switchgears<br>with SF <sub>6</sub> insulation (GIS) for<br>rated voltages above 52 kV | 27.12.10.190 | 8537 200000 | Measurement of electrical resistance  | (0 to 1000 Ω)<br>Compliant /<br>noncompliant  |
| 167 | IEC 62271-203 §7.5         |   |              |             | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance   | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω   |
| 168 | IEC 62271-203 §7.6         |   |              |             | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- control of time characteristics   | Passed / failed<br>0,1 to 320 kA<br>0,1 to 120 kA<br>0 to 30 min  |
| 169 | IEC 62271-203 §7.101       |   |              |             | Tests for switching capability:<br><br>- amplitude voltage<br>- RMS voltage<br>- RMS value of short-circuit current<br>- peak value of short-circuit current<br>- control of mechanical, electrical and<br>time characteristics | Compliant /<br>noncompliant<br>(0 to 308 kV)<br>(0 to 220 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 600 V);<br>(0 to 300 A);<br>(0 to 300 mm);<br>(0 to 30 min);<br>Compliant /<br>noncompliant |
| 170 | IEC 62271-203 §7.102.2     |   |              |             | Mechanical tests<br>(electromechanical tests):<br>- checking of operating mechanisms<br>cubicle and withdrawable element<br>- checking of switching of main circuit<br>equipment  | Compliant /<br>noncompliant<br>Compliant /<br>noncompliant  |



| 1   | 2                              | 3  | 4            | 5           | 6   | 7  |
|-----|--------------------------------|--|--------------|-------------|---|--|
|     |                                |  |              |             | - test of blockings   | Compliant / noncompliant   |
| 171 | IEC 62271-203 §7.105, Annex B  |  |              |             | Tests for exposure of electric arc (localization capability):<br>- highest service voltage<br>- short-circuit current<br>- peak value of short-circuit current<br>- control of time characteristics | Compliant / noncompliant<br>(0 to 40,5 kV)<br>(0 to 50 kA)<br>(0 to 135 kA)<br>(0 to 30 min) |
| 172 | IEC 62271-205 §6.4             | Compact switchgears for calculated voltage above 52 kV | 27.12.10.190 | 8537 200000 | Measurement of electrical resistance  | (0 to 1000 Ω)<br>Compliant / noncompliant  |
| 173 | IEC 62271-205 §6.5             |  |              |             | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance   | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω                            |
| 174 | IEC 62271-205 §6.6             |  |              |             | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- control of time characteristics   | Passed /failed<br>0,1 to 320 kA<br>0,1 to 120 kA<br>0 to 30 min                              |
| 175 | IEC 62271-205 §6.101.1-6.101.2 |  |              |             | Mechanical tests (electromechanical tests):<br>- checking of operating mechanisms cubicle and withdrawable element<br>- checking of switching of main circuit equipment<br>- test of blockings      | Compliant / noncompliant<br>Compliant / noncompliant<br>Compliant / noncompliant             |
| 176 | GOST 2213 §7.1                 | AC current fuses for voltage 3 kV and higher           | 27.12.10.140 | 8535 100000 | Tests for compliance to requirements to of construction and requirements assembling drawing, completeness, including during safety checking:<br>- geometrical, mounting and connecting dimensions   | (0 to 5000 mm)<br>Compliant / noncompliant<br>(0 to 10000 kg)                                |

| 1   | 2                      | 3 | 4 | 5 | 6   | 7   |
|-----|------------------------|---|---|---|---|---|
|     |                        |   |   |   | <ul style="list-style-type: none"> <li>- mass</li> <li>- condition of protective surfaces</li> <li>- condition of surface of external insulating parts</li> <li>- correctness of filling of nameplate</li> <li>- correctness of marking and branding</li> <li>- presence of trigger indicator and (or) striking devices and (or) devices for remote signalling, blocking and control</li> </ul> | <p>Compliant / noncompliant<br/>Compliant / noncompliant<br/>Compliant / noncompliant<br/>Compliant / noncompliant<br/>Compliant / noncompliant</p> <p>Compliant / noncompliant</p> |
| 177 | GOST 2213 §7.5         |   |   |   | <p>Temperature rise tests with rated current:</p> <ul style="list-style-type: none"> <li>- current</li> <li>- temperature rise</li> <li>- resistance</li> <li>- time</li> </ul>   | <p>Passed/ failed</p> <p>10 to 20 000 A<br/>1 to 300 °C<br/>1 μΩ to 2000 Ω<br/>1 ms to 30 min</p>   |
| 178 | GOST 2213 §7.6-1-7.6.4 |   |   |   | <p>Tests for mechanical capability and for mechanical wearing tests, including during safety checking:</p> <ul style="list-style-type: none"> <li>- control of mechanical characteristics, correct operation of device mechanisms and blockings</li> <li>- checking of forces</li> </ul>  | <p>(0 to 300 mm);<br/>(0 to 30 min);<br/>Compliant / noncompliant</p> <p>(0 to 10000 N)<br/>Compliant / noncompliant</p>  |
| 179 | GOST 2213 §7.7         |   |   |   | <p>Short-time withstand tests:</p> <ul style="list-style-type: none"> <li>- electrodynamic withstand current</li> <li>- thermal withstand current</li> <li>- time</li> </ul>  | <p>Passed / failed</p> <p>0,1 to 320 kA<br/>0,1 to 120 kA<br/>1 ms to 30 min</p>  |
| 180 | GOST 2213 §7.8-7.11    |   |   |   | Tests for switching capability:   | Compliant /   |

| 1   | 2                    | 3   | 4            | 5           | 6  | 7  |
|-----|----------------------|---|--------------|-------------|--|--|
|     |                      |   |              |             | - amplitude voltage<br>- RMS voltage<br>- short-circuit current<br>- peak value of short-circuit current<br>- control of time characteristics  | noncompliant<br>(0 to 80 kV)<br>(0 to 40,5 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 30 min)             |
| 181 | IEC 62271-105 §7.4   | Switch-fuse combination for AC current        | 27.12.10     | 8535        | Checking of electrical resistance  | (0 to 1000 Ω)<br>Compliant / noncompliant  |
| 182 | IEC 62271-105 §7.5   |   |              |             | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance<br>- time  | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω<br>1 ms to 30 min                          |
| 183 | IEC 62271-105 §7.6   |   |              |             | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- times  | Passed / failed<br>0,1 to 320 kA<br>0,1 to 120 kA<br>1 ms to 30 min  |
| 184 | IEC 62271-105 §7.101 |   |              |             | Tests for switching capability:<br><br>- amplitude voltage<br>- RMS voltage<br>- short-circuit current<br>- peak value of short-circuit current<br>- control of time characteristics | Compliant / noncompliant<br>(0 to 80 kV)<br>(0 to 40,5 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 30 min) |
| 185 | IEC 60282-1 §7.5     | High voltage fuses.<br>Current-limiting fuses | 27.12.10.140 | 8535 100000 | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance<br>- time  | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω<br>1 ms to 30 min                          |
| 186 | IEC 60282-1 §7.6-7.7 |   |              |             | Tests for switching capability:<br>- amplitude voltage<br>- RMS voltage<br>- short-circuit current<br>- peak value of short-circuit current<br>- control of time characteristics     | Compliant/noncompliant<br>(0 to 80 kV)<br>(0 to 40,5 kV)<br>(0 to 63 kA)<br>(0 to 170 kA)<br>(0 to 30 min)   |
| 187 | IEC 60282-1 § 8.3    |   |              |             | Control of mechanical characteristics,<br>trigger indicator and (or) striking devices<br>and (or) devices for remote signalling  | (0 to 300 mm);<br>(0 to 30 min);<br>Compliant /  |

| 1   | 2                     | 3                                     | 4            | 5           | 6   | 7   |
|-----|-----------------------|---------------------------------------|--------------|-------------|---|---|
|     |                       |                                       |              |             |   | Noncompliant  |
| 188 | IEC 60282-2 § 8.5     | High voltage fuses.<br>Striking fuses | 27.12.10.140 | 8535 100000 | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance<br>- time   | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω<br>1 msto 30 min  |
| 189 | IEC 60282-2 § 8.6-8.7 |                                       |              |             | Tests for switching capability:<br><br>- amplitude voltage<br>(0 to 80 kV)<br>- RMS voltage<br>(0 to 40,5 kV)<br>- short-circuit current<br>(0 to 63 kA)<br>- peak value of short-circuit current<br>(0 to 170 kA)<br>- control of time characteristics   | Compliant /<br>noncompliant<br>(0 to 80 kV)<br><br>(0 to 40,5 kV)<br><br>(0 to 63 kA)<br><br>(0 to 170 kA)<br><br>(0 to 30 min) |
| 190 | IEC 60282-2 § 8.8.2   |                                       |              |             | Tests for mechanical capability and for<br>mechanical wearing tests:<br>- control of mechanicalcharacteristics,<br>correct operation of device mechanisms<br>and blockings<br><br>- checking of forces  | (0 to 300 mm);<br>(0 to 30 min);<br>Compliant /<br>noncompliant<br>(0 to 10000 N)<br>Compliant /<br>Noncompliant                |
| 191 | GOST 20493 § 8.1, 8.2 | Voltage Indicators                    | 27.12.10.190 | 8535 90     | Visual control, checking of complete-<br>ness, of marking. Checking for compli-<br>ance to working drawings.<br>- checking of serviceability<br>- checking of completeness<br>- checking of package<br>- checking of marking<br>- checking of traces of corrosion<br>- condition of insulating surfaces | Compliant/<br>noncompliant  |

| 1   | 2                                  | 3   | 4            | 5       | 6  | 7                                 |
|-----|------------------------------------|---|--------------|---------|--|-----------------------------------|
|     |                                    |   |              |         | - checking of documentation  |                                   |
| 192 | GOST 20493 § 8.9.2, 8.9.3, 8.10.4, |   |              |         | Checking of value of indication voltage. Checking of voltage indicator for absence of indication from influence of adjacent circuits with same voltage   | Compliant/<br>noncompliant        |
| 193 | GOST 20493 § 8.9.4, 8.9.2          |   |              |         | Checking of value of current, flowing through voltage indicator during highest value of service voltage. Checking of serviceability of scheme  | Compliant/<br>noncompliant        |
| 194 | GOST 20493 § 8.10.8, 8.7           |   |              |         | Tests for bending. Mechanical tests.   | Passed / failed<br>0 to 10%       |
| 195 | GOST 20494 §§ 8.1-8.2              | Insulating operating rods and portable grounding rods | 27.12.10.190 | 8535 90 | Visual control, checking of completeness, of marking. Checking for compliance to working drawings.<br>- checking of serviceability<br>- checking of completeness<br>- checking of package<br>- checking of marking<br>- checking of traces of corrosion<br>- condition of insulating surfaces<br>- checking of documentation | Compliant/<br>noncompliant        |
| 196 | GOST 20494 § 8.5.2                 |   |              |         | Tests for bending. Mechanical tests.   | Passed / failed<br>0 to 10%       |
| 197 | GOST R 51853 § 9.1                 | Portable grounding for electrical installations       | 27.12.10.190 | 8535 90 | Visual control, checking of completeness, of marking. Checking for compliance to working drawings.<br>- checking of serviceability<br>- checking of completeness<br>- checking of package<br>- checking of marking<br>- checking of traces of corrosion<br>- condition of insulating surfaces<br>- checking of documentation | Compliant/<br>noncompliant        |
| 198 | GOST R 51853 §§ 9.4, 9.6           |   |              |         | Checking of conductor section.   | Passed / failed                   |
| 199 | GOST R 51853 § 9.5                 |   |              |         | Short-time withstand tests:<br>- electrodynamic withstand current  | Passed / failed<br>0,1 to 320 kA; |

| 1   | 2                                    | 3  | 4  | 5  | 6   | 7   |
|-----|--------------------------------------|--|--|--|---|---|
|     |                                      |  |  |  | - thermal withstand current<br>- measurement of resistance  | 0,1 to 120 kA;<br>1 $\mu\Omega$ to 2000 $\Omega$  |
| 200 | GOST R 51853 §9.3                    |  |  |  | Tests for bending   | Passed / failed<br>0 to 20%   |
| 201 | GOST 8008 sections 7; 8              | Devices for voltage control under load of power transformers                         | 27.12.10.190                             | 8504 900000                                  | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance                                       | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 $\mu\Omega$ to 2000 $\Omega$         |
| 202 | GOST R 55194 § 7.5                   | AC current Electrical equipment and Electrical installations for voltage 1 to 750 kV | 27.12.1<br>27.12.2<br>27.12.3<br>27.12.4 | 8504<br>8535<br>8536<br>8537<br>8544<br>8546 | Tests of electrical strength of insulation AC voltage of control circuits, auxiliary circuits (0 to 5 kV)                           | Passed / failed   |
| 203 | STO 56947007-29.060.10.117-2012 §6   | Rigid bus system (High-voltage busducts)   | 27.12.10.190                             | 8535 90 0000                                 | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance                                       | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 $\mu\Omega$ to 2000 $\Omega$         |
| 204 | STO 56947007-29.060.10.117-2012 §7,8 |  |  |  | Short-time withstand tests:<br><br>- electrodynamic withstand current<br>- thermal withstand current<br>- measurement of resistance | Passed / failed<br><br>0,1 to 320 kA;<br>0,1 to 120 kA;<br>1 $\mu\Omega$ to 2000 $\Omega$ |
| 205 | IEC 60353 §19.1                      | High-frequency line traps  | 27.12.10.190                             | 8535 900000                                  | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- resistance                                       | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 $\mu\Omega$ to 2000 $\Omega$         |
| 206 | IEC 60353 § 19.4                     |  |  |  | Tests for withstand during short-circuits<br>0,1 to 12 kV   | 0,1 to 40 kA<br>0,2 to 0,5 mH<br>0,1 to 2 s<br>compliant/<br>noncompliant                 |
| 207 | STO 96502166-123-2018                | Betelen resistors, resistor installations  | 27.12.10.190                             | 8533   | Measurement of resistance to 1000 $\Omega$  | compliant/<br>noncompliant  |
| 208 | STO 96502166-123-2018                |  |  |  | Checking of rated maximum permissible voltages to 85 kV   | Passed/ failed  |

| 1   | 2                                   | 3   | 4        | 5    | 6  | 7   |
|-----|-------------------------------------|---|----------|------|--|---|
| 209 | GOST 9098 §§6.2.1-6.2.3             | Low voltage switches for household and industrial purpose | 27.12.22 | 8536 | Visual control:<br>- geometrical dimensions<br>- mass  | Passed / failed<br>1 to 1000 mm<br>1 to 1000 kg   |
| 210 | GOST 9098 §6.2.5, 6.2.7, 6.7        |   |          |      | Control of forces of operating, joint (partition), marking. Trial montage and checking of mutual replacement                       | Compliant/<br>noncompliant  |
| 211 | GOST 9098 §§6.3.2-6.3.5; 6.3.14     |   |          |      | Tests for mechanical wearing tests and switching capability:<br>- current<br>- number of CO sequences<br>- times<br>- resistance   | Passed / failed<br><br>0,1 to 120 kA<br>1 to 10 000<br>1 ms to 60 min<br>1 $\mu\Omega$ to 2000 $\Omega$ |
| 212 | GOST 9098 § 6.3.11; 6.3.13          |   |          |      | Control of return factor. Control of working of interruptors and motor:<br>- current<br>- temperature rise<br>- times<br>- voltage | Compliant/<br>noncompliant<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C<br>1 ms to 60 min<br>1 to 400 V |
| 213 | GOST 9098 § 6.3.7                   |   |          |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise  | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C  |
| 214 | GOST 9098 § 6.3.9                   |   |          |      | Insulation resistance.   | Passed / failed<br>1 $\kappa\Omega$ to 70 G $\Omega$  |
| 215 | GOST IEC 60947-2 §8.2               | Low voltage switches for household and industrial purpose | 27.12.22 | 8536 | Visual control:<br>- geometrical dimensions<br>- mass  | Passed / failed<br>1 to 1000 mm<br>1 to 1000 kg   |
| 216 | GOST IEC 60947-2 §5.2, 5.3, 8.3.3.4 |   |          |      | Control of forces of operating, joint (partition), marking. Trial montage and checking of mutual replacement                       | Compliant/<br>noncompliant  |
| 217 | GOST IEC 60947-2 §8.3.4.2, 8.3.5.3  |   |          |      | Tests for mechanical wearing tests and switching capability:<br>- current<br>- number of CO sequences                              | Passed / failed<br><br>0,1 to 120 kA<br>1 to 10 000   |

| 1   | 2  | 3   | 4        | 5    | 6   | 7   |
|-----|--|---|----------|------|---|---|
|     |  |   |          |      | - times<br>- resistance   | 1 ms to 60 min<br>1 $\mu\Omega$ to 2000 $\Omega$  |
| 218 | GOST IEC 60947-2 §8.3.3.2, 8.3.3.8, 8.3.4.6, 8.3.5.2, 8.3.5.5, 8.3.6.2, 8.3.6.7, 8.3.7.5, 8.3.7.9, 8.3.8.2, 8.3.8.8      |   |          |      | Control of return factor. Control of working of interruptors and motor:<br>- current<br>- temperature rise<br>- times<br>- voltage    | Compliant/<br>noncompliant<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C<br>1 ms to 60 min<br>1 to 400 V     |
| 219 | GOST IEC 60947-2 § 8.3.2.5, 8.3.3.7, 8.3.4.4, 8.3.6.4, 8.3.7.3, 8.3.8.7  |   |          |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise   | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C  |
| 220 | GOST R 50030.2 §8.2  | Low voltage switches for household and industrial purpose | 27.12.22 | 8536 | Visual control:<br>- geometrical dimensions<br>- mass   | Passed / failed<br>1 to 1000 mm<br>1 to 1000 kg   |
| 221 | GOST R 50030.2 §8.3.3  |   |          |      | Control of forces of operating, joint (partition), marking. Trial montage and checking of mutual replacement                          | Compliant/<br>noncompliant  |
| 222 | GOST R 50030.2 §8.3.2.6.1, 8.3.2.6.2, 8.3.5.3, 8.3.4.1, 8.3.8.3  |   |          |      | Tests for mechanical wearing tests and switching capability:<br>- current<br>- number of CO sequences<br>- times<br>- resistance      | Passed / failed<br><br>0,1 to 120 kA<br>1 to 10 000<br>1 ms to 60 min<br>1 $\mu\Omega$ to 2000 $\Omega$     |
| 223 | GOST R 50030.2 §8.3.3.18.3.3.7, 8.3.4.5, 8.3.5.1, 8.3.5.4, 8.3.6.1, 8.3.6.6, 8.3.7.4, 8.3.7.4, 8.3.7.8, 8.3.8.1, 8.3.8.7 |   |          |      | Control of return factor.<br>Control of working of interruptors and motor:<br>- current<br>- temperature rise<br>- times<br>- voltage | Compliant/<br>noncompliant<br><br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C<br>1 ms to 60 min<br>1 to 400 B |
| 224 | GOST R 50030.2 §8.3.2.5, 8.3.3.6, 8.3.4.4, 8.3.6.3, 8.3.7.2, 8.3.8.6   |   |          |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise   | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C  |



| 1   | 2  | 3   | 4        | 5    | 6  | 7  |
|-----|--|---|----------|------|--|--|
| 225 | GOST R 50030.2 §8.3.3.2  |   |          |      | Insulation resistance.   | Passed / failed<br>1 κΩ to 70 GΩ   |
| 226 | GOST IEC 60947-6-2 § 9.2   | Low voltage switches for household and industrial purpose | 27.12.22 | 8536 | Visual control:<br>- geometrical dimensions<br>- mass  | Passed / failed<br>1 to 1000 mm<br>1 to 1000 kg  |
| 227 | GOST IEC 60947-6-2 § 8.1.7.4, Annex C  |   |          |      | Control of forces of operating, joint (partition), marking. Trial montage and Checking of mutual replacement                       | Compliant/<br>noncompliant   |
| 228 | GOST IEC 60947-6-2 § 8.2.4.3, 9.4.3.1, Annex A                                     |   |          |      | Tests for mechanical wearing tests and switching capability:<br>- current<br>- number of sequencesBO<br>- times<br>- resistance    | Passed / failed<br>0,1 to 120 kA<br>1 to 10 000<br>1 ms to 60 min<br>1 μΩ to 2000 Ω        |
| 229 | GOST IEC 60947-6-2 § 9.4.1.2, 9.4.1.3, 9.4.3.5, 9.4.4.1, 9.4.4.6                   |   |          |      | Control of return factor. Control of working of interruptors and motor:<br>- current<br>- temperature rise<br>- times<br>- voltage | Compliant/<br>noncompliant<br>10 to 20 000 A<br>1 to 300°C<br>1 ms to 60 min<br>1 to 400 V |
| 230 | GOST IEC 60947-6-2 § 9.3.3.3, 9.4.1.1, 9.4.4.5                                     |   |          |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise  | Passed / failed<br>10 to 20 000 A<br>1 to 300°C  |
| 231 | GOST IEC 60947-6-2 § 9.4.1.4, 9.4.2.3, 9.4.3.4, 9.4.4.4, 9.4.5.3, 9.4.6.3, 9.4.7.3 |   |          |      | Insulation resistance.   | Passed / failed<br>1 κΩ to 70 GΩ   |
| 232 | GOST IEC 60947-6-1 § 9.2   | Low voltage switches for household and industrial purpose | 27.12.22 | 8536 | Visual control:<br>- geometrical dimensions<br>- mass  | Passed / failed<br>1 to 1000 mm<br>1 to 1000 kg  |
| 233 | GOST IEC 60947-6-1 § 8.1.2   |   |          |      | Control of forces of operating, joint (partition), marking. Trial montage and Checking of mutual replacement                       | Compliant/<br>noncompliant   |
| 234 | GOST IEC 60947-6-1 § 9.3.3.5, 9.3.3.6.2  |   |          |      | Tests for mechanical wearing tests and switching capability:<br>- current<br>- number of CO sequences<br>- times                   | Passed / failed<br>0,1 to 120 kA<br>1 to 10 000<br>1 ms to 60 min                          |

| 1   | 2                                     | 3  | 4        | 5    | 6  | 7   |
|-----|---------------------------------------|--|----------|------|--|---|
|     |                                       |  |          |      | - resistance   | 1 $\mu\Omega$ to 2000 $\Omega$  |
| 235 | GOST IEC 60947-6-1 § 9.3.3.1, 9.3.3.2 |  |          |      | Control of return factor. Control of working of interruptors and motor:<br>- current<br>- temperature rise<br>- times<br>- voltage | Compliant/<br>noncompliant<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C<br>1 ms to 60 min<br>1 to 400 V |
| 236 | GOST IEC 60947-6-1 § 8.3.3            |  |          |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise  | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C  |
| 237 | GOST IEC 60947-6-1 § 8.3.3.4.1        |  |          |      | Insulation resistance.   | Passed / failed<br>1 $\kappa\Omega$ to 70 G $\Omega$  |
| 238 | GOST IEC 60898-1 § 9.3-9.4            | Low voltage switches for household and industrial purpose    | 27.12.22 | 8536 | Control of marking. Checking of reliability of screws, terminals   | Compliant/<br>noncompliant  |
| 239 | GOST IEC 60898-1 § 9.11               |  |          |      | Tests for mechanical wearing tests and switching capability:<br>- current<br>- number of CO sequences<br>- times<br>- resistance   | Passed / failed<br><br>0,1 to 120 kA<br>1 to 10 000<br>1 ms to 60 min<br>1 $\mu\Omega$ to 2000 $\Omega$ |
| 240 | GOST IEC 60898-1 § 9.10               |  |          |      | Control of return factor. Control of working of interruptors and motor:<br>- current<br>- temperature rise<br>- times<br>- voltage | Compliant/<br>noncompliant<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C<br>1 ms to 60 min<br>1 to 400 V |
| 241 | GOST IEC 60898-1 § 9.8; 9.9           |  |          |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise  | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C  |
| 242 | GOST IEC 60898-1 § 9.7                |  |          |      | Insulation resistance.   | Passed / failed<br>1 $\kappa\Omega$ to 70 G $\Omega$  |
| 243 | GOST 17242 §§7.2; 8.1                 | Fuses voltage to 1000 V for household and industrial purpose | 27.12.21 | 8536 | Requirements to construction.<br>- geometrical dimensions<br>- mass<br>Checking of mutual replacement.<br>- Checking of marking    | Passed / failed<br>1 to 1000 mm<br>0,1 to 1000 kg   |



| 1   | 2                      | 3  | 4        | 5    | 6   | 7  |
|-----|------------------------|--|----------|------|---|--|
|     |                        |  |          |      | <ul style="list-style-type: none"> <li>- checking of mass</li> <li>- checking of geometrical dimensions</li> <li>- checking of mutual replacement</li> <li>- Trial montage</li> </ul> | 0 to 100 kg<br>Compliant/<br>noncompliant<br>1 to 5 000 mm<br>Compliant/<br>noncompliant<br>Compliant/<br>noncompliant               |
| 249 | GOST 2933 §5, 6        |  |          |      | Requirements to temperature rise:<br>- current<br>- temperature rise<br>Over-load capability:<br>- current<br>- resistance<br>- Checking of power losses,<br>- electrical resistance  | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C<br><br>10 to 20000 A<br>1 μΩ to 2000 Ω<br>1 to 2000 W<br>1 μΩ to 2000 Ω |
| 250 | GOST 2933 §8           |  |          |      | Requirements to switching capability:<br>- number of sequences<br>- current   | Passed / failed<br>1 to 1000 sequences<br>10 to 35 000 A   |
| 251 | GOST 2933 §10          |  |          |      | Test for mechanical and switching wear-<br>ing tests:<br>- number of sequences<br>- resistance  | Passed / failed<br><br>1 to 10 000 sequences<br>1 μΩ to 2000 Ω   |
| 252 | GOST 2933 Section 9    |  |          |      | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current  | Passed / failed<br>0,1 to 320 kA;<br>0,1 to 120 kA   |
| 253 | GOST 2327 §6.2         | Low-voltage thrust-in switches, disconnectors, switches-disconnectors, selectors and selectors-disconnectors for voltage to 1000 V | 27.33.11 | 8536 | Requirements to of construction, Mark-<br>ing, Montage<br>- geometrical dimensions<br>- mass<br>- Checking of forces for handling<br>- Checking of contact pressure                   | Compliant/<br>noncompliant<br>1 to 1000 mm<br>0,1 to 1000 kg<br>0,1 to 1000 N<br>0,1 to 1000 N                                       |
| 254 | GOST 2327 §6.3.1-6.3.2 |  |          |      | Control of apparatuses for compliance to requirements to electrical parameters and duties:  | Compliant/<br>noncompliant   |

| 1   | 2   | 3  | 4        | 5    | 6   | 7  |
|-----|---|--|----------|------|---|--|
|     |   |  |          |      | - Power-frequency test voltage<br>- Insulation resistance.  | 0,1 to 5 kV<br>1 kΩ to 70 GΩ   |
| 255 | GOST 2327 §6.3.7  |  |          |      | Requirements to temperature rise:<br>- current<br>- temperature rise<br>- resistance  | Passed / failed<br>10 to 20 000 A<br>1 to 300°C<br>1 μΩ to 2000 Ω                              |
| 256 | GOST 2327 §6.3.3  |  |          |      | Switching capability and wearing tests:<br>- number of sequences<br>- resistance<br>- current   | Passed / failed<br>0 to 100 000 sequences<br>1 μΩ to 2000 Ω<br>0,1 to 120 kA                   |
| 257 | GOST 2327 §6.3.6  |  |          |      | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current  | Passed / failed<br>0,1 to 320 kA;<br>0,1 to 120 kA;  |
| 258 | GOST 2327-89 §6.3.4   |  |          |      | Requirements to mechanical withstand and wearing:<br>- number of sequences<br>- resistance<br>- current   | Passed / failed<br>0 to 100 000 sequences<br>0 to 2000 Ω<br>0 to 20 000 A                      |
| 259 | GOST R 50030.3 §8.2, 8.3.3.7  | Automatic thrust-in low-voltage switches, disconnectors, switches-disconnectors, selectors and selectors-disconnectors for voltage to 1000 V | 27.33.11 | 8536 | Requirements to construction, Marking, Montage<br>- geometrical dimensions<br>- mass<br>- Checking of forces for handling<br>- Checking of contact pressure | Compliant/<br>noncompliant<br>1 to 1000 mm<br>0,1 to 1000 kg<br>0,1 to 1000 N<br>0,1 to 1000 N |
| 260 | GOST R 50030.3 §8.1.3.3, 8.3.3.2, 8.3.3.4, 8.3.7.2, 8.3.6.3, 8.3.5.3, 8.3.4.2 |  |          |      | Control of apparatuses for compliance to requirements to electrical parameters and duties:<br>- Power-frequency test voltage<br>- Insulation resistance.    | Compliant/<br>noncompliant<br><br>0,1 to 5 kV<br>1 to 70 GΩ                                    |
| 261 | GOST R 50030.3 §8.3.3.1, 8.3.3.6, 8.3.4.4, 8.3.5.5, 8.3.6.5, 8.3.7.1, 8.3.7.4 |  |          |      | Requirements to temperature rise:<br>- current<br>- temperature rise<br>- resistance  | Passed / failed<br>10 to 20 000 A<br>1 to 300°C<br>1 μΩ to 2000 Ω                              |

| 1   | 2  | 3   | 4        | 5            | 6  | 7  |
|-----|--|---|----------|--------------|--|--|
| 262 | GOST R 50030.3 §8.3.3.3, 8.3.4.1, 8.3.5.2, 8.3.6.2.1 |   |          |              | Switching capability and wearing tests:<br>- number of sequences<br>- resistance<br>- current                | Passed / failed<br>0 to 100 000 sequences<br>1 $\mu\Omega$ to 2000 $\Omega$<br>0,1 to 120 kA   |
| 263 | GOST R 50030.3 §8.3.5.1, 8.3.6.2.1                   |   |          |              | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current             | Passed / failed<br>0,1 to 320 kA;<br>0,1 to 120 kA;  |
| 264 | GOST 19132 §§6.4; 6,5                                | Type setting contact terminals<br>Contact connections<br>- separable<br>- non-separable | 27.33.11 | 8535<br>8536 | Checking of construction. Marking.<br>Montage<br>- geometrical dimensions<br>- mass<br>- Checking of marking | Compliant/<br>noncompliant<br>1 to 1000 mm<br>0,1 to 100 kg                                    |
| 265 | GOST 19132 §§6.10-6.13                               |   |          |              | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- electrical resistance     | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C<br>1 $\mu\Omega$ to 2000 $\Omega$ |
| 266 | GOST 19132 §§6.11; 6.14                              |   |          |              | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current             | Passed / failed<br><br>0,1 to 320 kA;<br>0,1 to 120 kA;  |
| 267 | GOST R 51155 § 5.1.4-5.1.6                           | Line fittings<br>Contact connections<br>- separable<br>- non-separable                  | 27.33.11 | 8535<br>8536 | Checking of construction. Marking.<br>Montage<br>- geometrical dimensions<br>- mass<br>- Checking of marking | Compliant/<br>noncompliant<br>1 to 1000 mm<br>0,1 to 100 kg                                    |
| 268 | GOST R 51155 §5.3, 5.12                              |   |          |              | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- electrical resistance     | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C<br>1 $\mu\Omega$ to 2000 $\Omega$ |

| 1   | 2                            | 3  | 4        | 5            | 6   | 7   |
|-----|------------------------------|--|----------|--------------|---|---|
| 269 | GOST R 51155 §5.3.8          |  |          |              | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current  | Passed / failed<br>0,1 to 320 kA;<br>0,1 to 120 kA;                                 |
| 270 | GOST 23981 §§5.1; 5.2; 5.7   | Cable tips<br>Contact connections<br>- separable<br>- non-separable    | 27.33.11 | 8535<br>8536 | Checking of construction. Marking.<br>Montage<br>- geometrical dimensions<br>- mass<br>- Checking of marking                                      | Compliant/<br>noncompliant<br>1 to 1000 mm<br>0,1 to 100 kg                         |
| 271 | GOST 23981 §5.6              |  |          |              | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- electrical resistance  | Passed / failed<br>10 to 20 000 A<br>1 to 300°C<br>1 μΩ to 2000 Ω                   |
| 272 | GOST 23981 §5.6              |  |          |              | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- temperature rise<br>- electrical resistance | Passed / failed<br>0,5 to 320 kA;<br>0,5 to 120 kA;<br>1 to 300°C<br>1 μΩ to 2000 Ω |
| 273 | GOST 2744 § 2.14, 2.16       | Line fittings<br>Contact connections<br>- separable<br>- non-separable | 27.33.11 | 8535<br>8536 | Checking of construction. Marking.<br>Montage<br>- geometrical dimensions<br>- mass<br>- Checking of marking                                      | Compliant/<br>noncompliant<br>1 to 1000 mm<br>0,1 to 100 kg                         |
| 274 | GOST 2744 §§2.20             |  |          |              | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- electrical resistance  | Passed / failed<br>10 to 20 000 A<br>1 to 300°C<br>1 μΩ to 2000 Ω                   |
| 275 | GOST 2744 §2.20              |  |          |              | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- temperature rise<br>- electrical resistance | Passed / failed<br>0,5 to 320 kA;<br>0,5 to 120 kA;<br>1 to 300°C<br>1 μΩ to 2000 Ω |
| 276 | GOST 17441-84 §§2.2.1-2.2.6; | Contact electrical connections   | 27.33.11 | 8535<br>8536 | Checking of construction. Marking.<br>Montage<br>- geometrical dimensions<br>- mass<br>- Checking of marking                                      | Compliant/<br>noncompliant<br>1 to 1000 mm<br>0,1 to 100 kg                         |

| 1   | 2  | 3   | 4                            | 5    | 6  | 7  |
|-----|--|---|------------------------------|------|--|--|
| 277 | GOST 17441 §§ 2.6; 2.7; 2.8; 2.10                  |   |                              |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- electrical resistance   | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C<br>1 μΩ to 2000 Ω                       |
| 278 | GOST 17441 §§ 2.9                                  |   |                              |      | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- temperature rise<br>- electrical resistance  | Passed / failed<br><br>0,5 to 320 kA;<br>0,5 to 120 kA;<br>1 to 300 <sup>0</sup> C<br>1 μΩ to 2000 Ω |
| 279 | GOST 2491 §§6.1                                    | Electromagnetic low-voltage starters      | 27.33.13.140<br>27.33.13.150 | 8536 | Checking of construction. Marking. Montage<br>- geometrical dimensions<br>- mass<br>- checking of marking  | Compliant/<br>noncompliant<br>1 mm to 1000 mm<br>0,1 to 100 kg                                       |
| 280 | GOST 2491 §§6.1; 6.2                               |   |                              |      | Power-frequency test voltage   | Passed / failed<br>- 0,5 to 5 kV   |
| 281 | GOST 2491 §6.1                                     |   |                              |      | Temperature rise tests with rated current, Checking of actuation and return, resistance and electrical strength of insulation at heated condition:<br>- current<br>- resistance<br>- electrical strength of insulation | Passed / failed<br><br>1 to 20 000 A<br>1 μΩ to 2000 Ω<br>1 κΩ to 70 GΩ                              |
| 282 | GOST 2491 §§6.1; 6.4; 6.8-6.10                     |   |                              |      | Switching capability and switching wearing tests<br>- number of sequences<br>- resistance<br>- current   | Passed / failed<br><br>0 to 100 000 sequences<br>1 μΩ to 2000 Ω<br>0,1 to 120 kA                     |
| 283 | GOST 2491 §6.11                                    |   |                              |      | Requirements to mechanical wearing:<br>- number of sequences<br>- resistance<br>- current  | Passed / failed<br><br>0 to 100 000 sequences<br>1 μΩ to 2000 Ω<br>10 to 20 000 A                    |
| 284 | GOST IEC 60947-4-1 § 8.2.3, 9.3.3.4                | Electromechanical contactors and starters | 27.33.13.140<br>27.33.13.150 | 8536 | Power-frequency test voltage   | Passed / failed<br>0,5 to 5 kV   |
| 285 | GOST IEC 60947-4-1 § 8.2.1, 8.2.2, 9.3.3.1-9.3.3.3 |   |                              |      | Temperature rise tests with rated current, Checking of actuation and return, re-   | Passed / failed  |



| 1   | 2   | 3  | 4        | 5    | 6   | 7  |
|-----|---|--|----------|------|---|--|
|     |   |  |          |      | sistance and electrical strength of insulation at heated condition:<br>- current<br>- resistance<br>- electrical strength of insulation           | 1 to 20 000 A<br>1 $\mu\Omega$ to 2000 $\Omega$<br>1 $\kappa\Omega$ to 70 G $\Omega$                             |
| 286 | GOST IEC 60947-4-1 § 8.2.4, 9.3.3.5                       |  |          |      | Switching capability and switching wearing tests<br>- number of sequences<br>- resistance<br>- current  | Passed / failed<br>0 to 100 000 sequences<br>1 $\mu\Omega$ to 2000 $\Omega$<br>0,1 to 120 kA                     |
| 287 | GOST IEC 60947-4-1 § 8.2.4, 9.3.3.5                       |  |          |      | Requirements to mechanical wearing:<br>- number of sequences<br>- resistance<br>- current   | Passed / failed<br>0 to 100 000 sequences<br>1 $\mu\Omega$ to 2000 $\Omega$<br>10 to 20 000 A                    |
| 288 | GOST IEC 60947-4-1 § 8.2.5, 9.3.4                         |  |          |      | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- temperature rise<br>- electrical resistance | Passed / failed<br>0,5 to 320 kA;<br>0,5 to 120 kA;<br>1 to 300 <sup>0</sup> C<br>1 $\mu\Omega$ to 2000 $\Omega$ |
| 289 | GOST IEC 61439-1 §§ 10.4; 10.9; 11.3; 11.9; Annex F, G, L | Low-voltage switchgears and controlgears (NKU) | 27.12.31 | 8537 | Power-frequency test voltage<br>Air gaps and creepage distance<br>Insulation resistance.  | Passed / failed<br>0,5 to 5 kV<br>1 to 1000 mm<br>1 $\kappa\Omega$ to 70G $\Omega$                               |
| 290 | GOST IEC 61439-1 §§10.8; 10.10; Annex A, E, H, M, N, O    |  |          |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise   | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup>   |
| 291 | GOST IEC 61439-1 §§10.5.3; 10.11; Annex B, P              |  |          |      | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current  | Passed / failed<br>0,1 to 320 kA;<br>0,1 to 120 kA   |
| 292 | GOST IEC 61439-1 §10.13                                   |  |          |      | Mechanical capability   | Passed / failed  |

| 1   | 2  | 3  | 4        | 5    | 6  | 7  |
|-----|--|--|----------|------|--|--|
|     |  |  |          |      | - number of operating sequences<br>- Checking of operating characteristics   | 1 to 50 sequences  |
| 293 | GOST 32396 §§9.17; 9.31-9.33                             | Input-distributive devices for living and public buildings (NKU)                             | 27.12.31 | 8537 | Power-frequency test voltage<br>Air gaps and creepage distance<br>Insulation resistance.   | Passed / failed<br>0,5 to 5 kV<br>1 to 1000 mm<br>1 κΩ to 70GΩ                                     |
| 294 | GOST 32396 §§9.29  |  |          |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise  | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup>   |
| 295 | GOST 32396 §§9.24; 9.30                                  |  |          |      | Short-time withstand tests:<br><br>- electrodynamic withstand current<br>- thermal withstand current   | Passed / failed<br><br>0,1 to 320 kA;<br>0,1 to 120 kA   |
| 296 | GOST 32396 §§9.9; 9.10; 9.25                             |  |          |      | Mechanical capability:<br>- number of operating sequences<br>- Checking of operating characteristics   | Passed / failed<br>1 to 50 sequences   |
| 297 | GOST IEC 60439-3 §§8.2.1; 8.2.3.1                        | Low-voltage switchgears and controlgears (NKU)   | 27.12.31 | 8537 | Temperature rise tests with rated current:<br>- current<br>- Insulation resistance.<br>- temperature rise  | Passed / failed<br>10 to 20 000 A<br>1 κΩ to 70 GΩ<br>1 to 300 <sup>0</sup>                        |
| 298 | GOST IEC 60439-3 §§8.2.3; 8.2.4; 8.2.4.1; 8.2.4.2; 8.3.3 |  |          |      | Short-time withstand tests:<br><br>- electrodynamic withstand current<br>- thermal withstand current<br>- temperature rise<br>- resistance with protective bus | Passed / failed<br><br>0,5 to 320 kA;<br>0,5 to 120 kA;<br>1 to 300 <sup>0</sup><br>1 μΩ to 2000 Ω |
| 299 | GOST IEC 60439-3 §§8.2.6; 8.2.15                         |  |          |      | Mechanical capability:<br>- number of operating sequences<br>- Checking of operating characteristics   | Passed / failed<br>1 to 50 sequences   |
| 300 | GOST R IEC 61439-2 §11.8                                 | Low-voltage switchgears and controlgears.<br>Power switchgears                               | 27.12.31 | 8537 | Mechanical capability:<br>- number of operating sequences<br>- checking of operating characteristics   | Passed / failed<br>1 to 50 sequences   |
| 301 | GOST 32395 §§10.26-10.28                                 | Distributive shields, input-distributive devices for industrial, living and public buildings | 27.12.31 | 8537 | Power-frequency test voltage<br>Air gaps and creepage distance<br>Insulation resistance.   | Passed / failed<br>- 0,5 to 5 kV<br>- 1 to 1000 mm<br>1 κΩ to 70GΩ                                 |

| 1   | 2                                 | 3  | 4        | 5    | 6 | 7  |  |
|-----|-----------------------------------|--|----------|------|---|--|--|
| 302 | GOST 32395 §10.25                 |  |          |      |   | Temperature rise tests with rated current:<br>- current<br>- Insulation resistance.<br>- temperature rise  | Passed / failed<br>1 to 20 000 A<br>1 κΩ to 70 GΩ<br>1 to 300 <sup>0</sup>                       |
| 303 | GOST 32395 §10.7                  |  |          |      |   | Mechanical capability:<br>- number of operating sequences<br>- Checking of operating characteristics   | Passed / failed<br>1 to 50 sequences   |
| 304 | GOST 32397 §§10.24; 10.25         | Distributive shields for industrial and public buildings     | 27.12.31 | 8537 |   | Power-frequency test voltage<br>Air gaps and creepage distance<br>Insulation resistance.   | Passed / failed<br>- 0,5 to 5 kV<br>- 1 to 1000 mm<br>1 κΩ to 70GΩ                               |
| 305 | GOST 32397 § 10.23                |  |          |      |   | Temperature rise tests with rated current:<br>- current<br>- Insulation resistance.<br>- temperature rise  | Passed / failed<br>1 to 20 000 A<br>1 κΩ to 70 GΩ<br>1 to 300 <sup>0</sup>                       |
| 306 | GOST 32397 §§10.12; 10.27         |  |          |      |   | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- temperature rise<br>- resistance with protective bus | Passed / failed<br>0,5 to 320 kA;<br>0,5 to 120 kA;<br>1 to 300 <sup>0</sup> C<br>1 μΩ to 2000 Ω |
| 307 | GOST 32397 §10.7                  |  |          |      |   | Mechanical capability:<br>- number of operating sequences<br>- Checking of operating characteristics   | Passed / failed<br>1 to 50 sequences   |
| 308 | GOST 6815 §§6.1; 6.1a; 6.15; 6.16 | Magistral and distributive busducts for AC voltage to 1000 V | -        | 8544 |   | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass  | Compliant/noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg   |
| 309 | GOST 6815 §§6.6; 6.14             |  |          |      |   | Power-frequency test voltage<br>Insulation resistance.   | Passed / failed<br>- 0,5 to 5 kV<br>1 κΩ to 70 GΩ  |
| 310 | GOST 6815 §§6.3; 6.10             |  |          |      |   | Temperature rise tests with rated current:<br>- current<br>- temperature rise  | Passed / failed<br>1 to 20 000 A<br>1 to 300 <sup>0</sup>  |
| 311 | GOST 6815 §6.12                   |  |          |      |   | Short-time withstand tests:<br>- electrodynamic withstand current  | Passed / failed  |

| 1   | 2                            | 3   | 4 | 5    | 6  | 7  |
|-----|------------------------------|---|---|------|--|--|
|     |                              |   |   |      | - thermal withstand current<br>- resistance of safety conductor  | 0,5 to 320 kA;<br>0,5 to 120 kA;<br>1 $\mu\Omega$ to 2000 $\Omega$                                     |
| 312 | GOST 6815 §6.2, 6.2a         |   |   |      | Mechanical capability:<br>- number of sequences<br>- load  | Passed / failed<br>1 to 50 sequences<br>1 to 10 000 kg   |
| 313 | GOST 24752 §§5.1; 5.12; 5.14 | Trolley busducts for voltage to 1000 V    | - | 8544 | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass<br>- resistance of safety conductor              | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 $\mu\Omega$ to 2000 $\Omega$         |
| 314 | GOST 24752 §§5.7; 5.12       |   |   |      | Power-frequency test voltage<br>Insulation resistance.<br>- resistance of safety conductor   | Passed / failed<br>- 0,5 to 5 kV<br>1 $\kappa\Omega$ to 70G $\Omega$<br>1 $\mu\Omega$ to 2000 $\Omega$ |
| 315 | GOST 24752 §§5.4; 5.6        |   |   |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise  | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup>   |
| 316 | GOST 24752 §5.5              |   |   |      | Short-time withstand tests:<br><br>- electrodynamic withstand current<br>- thermal withstand current<br>- resistance of safety conductor | Passed / failed<br><br>0,1 to 320 kA;<br>0,1 to 120 kA;<br>1 $\mu\Omega$ to 2000 $\Omega$              |
| 317 | GOST 26346 §§6.1; 6.18       | Lighting busducts for AC voltage to 660 V | - | 8544 | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass<br>- resistance of safety conductor              | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 $\mu\Omega$ to 2000 $\Omega$         |
| 318 | GOST 26346 §6.5              |   |   |      | Power-frequency test voltage<br>Insulation resistance.<br>- resistance of safety conductor   | Passed / failed<br>- 0,5 to 5 kV<br>1 $\kappa\Omega$ to 70G $\Omega$<br>1 $\mu\Omega$ to 2000 $\Omega$ |
| 319 | GOST 26346 §§6.3; 6.13       |   |   |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise  | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup>   |

| 1   | 2  | 3  | 4            | 5           | 6   | 7   |
|-----|--|--|--------------|-------------|---|---|
| 320 | GOST 26346 §6.4  |  |              |             | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- resistance of safety conductor  | Passed / failed<br><br>0,1 to 320 kA;<br>0,1 to 120 kA;<br>1 $\mu\Omega$ to 2000 $\Omega$                                     |
| 321 | GOST R 51321.2 §§ 7.1.2.3.4;<br>7.1.2.3.5              | Busducts.<br>Low-voltage switchgears<br>and controlgears             | -            | 8544        | Power-frequency test voltage<br>Insulation resistance.<br>- resistance of safety conductor  | Passed / failed<br>- 0,5 to 5 kV<br>1 $\kappa\Omega$ to 70G $\Omega$<br>1 $\mu\Omega$ to 2000 $\Omega$                        |
| 322 | GOST R 51321.2 §§ 8.2.1;<br>8.2.11; 8.2.13; Annex J; N |  |              |             | Temperature rise tests with rated current:<br>- current<br>- temperature rise   | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup>  |
| 323 | GOST R 51321.2 §§8.2.3; 8.2.13                         |  |              |             | Short-time withstand tests:<br><br>- electrodynamic withstand current<br>- thermal withstand current<br>- resistance of safety conductor  | Passed / failed<br><br>0,1 to 320 kA;<br>0,1 to 120 kA;<br>1 $\mu\Omega$ to 2000 $\Omega$                                     |
| 324 | GOST R 51321.2 §8.2.10                                 |  |              |             | Test for mechanical strength  | Passed / failed<br>- 1 to 10 000 kg   |
| 325 | GOST 10693 §6.2  | Capacitive sealed bushings<br>for rated voltage 110 kV and<br>higher | 27.90.12.120 | 8546 900000 | Tests for compliance to requirements<br>assembling drawing, including during<br>safety checking:<br>- geometrical, mounting and connecting<br>dimensions<br><br>- absence of visible defects        | (0 to 5000 mm)<br>Compliant /<br>noncompliant<br>Compliant /<br>noncompliant  |
| 326 | GOST 10693 §6.6  |  |              |             | Tests for withstand:<br>During short-circuit current:<br>- electrodynamic withstand current<br><br>- thermal withstand current<br><br>During switching:<br>- amplitude voltage<br><br>- RMS voltage | (0 to 320 kA)<br>Passed / failed<br>(0 to 120 kA)<br>Passed / failed<br><br>(0 to 308 kV)<br>Passed / failed<br>(0 to 220 kV) |

| 1   | 2                  | 3  | 4            | 5           | 6  | 7   |
|-----|--------------------|--|--------------|-------------|--|---|
|     |                    |  |              |             | <ul style="list-style-type: none"> <li>- RMS value of short-circuit current</li> <li>- peak value of short-circuit current</li> <li>- control mechanical and time characteristics</li> </ul> | Passed / failed<br>(0 to 63 kA)<br>Passed / failed<br>(0 to 170 kA)<br>Passed / failed<br>(0 to 30 min);<br>Compliant /<br>noncompliant |
| 327 | GOST 10693 §6.7    |  |              |             | Temperature rise tests with rated current:<br>- current<br>- temperature rise  | Passed/ failed<br>10 to 20 000 A<br>1 to 300 °C   |
| 328 | GOST 10693 §6.8    |  |              |             | Checking of electrical resistance  | 0 to 1000 Ω<br>Compliant /<br>noncompliant  |
| 329 | GOST 10693 §6.9    |  |              |             | Measurement of Insulation resistance of measuring or special terminals   | 1000 to 2500 V<br>0 to 50 000 MΩ<br>Compliant /<br>Noncompliant   |
| 330 | GOST 10693 §6.13   |  |              |             | Test for mechanical wearing tests to 50 000 sequences  | Passed/ failed  |
| 331 | GOST R 55187 §9.1  | Insulated bushings for rated voltage above 1000 V AC current | 27.90.12.120 | 8546 900000 | Tests for compliance to requirements assembling drawing, including during safety checking:<br>- geometrical, mounting and connecting dimensions<br><br>- absence of visible defects          | 0 to 5000 mm<br>Compliant /<br>noncompliant<br>Compliant /<br>noncompliant  |
| 332 | GOST R 55187 §9.4  |  |              |             | Measurement of Insulation resistance of measuring or special terminals   | 1000 to 2500 V<br>0 to 50 000 MΩ<br>Compliant /<br>noncompliant   |
| 333 | GOST R 55187 §9.6  |  |              |             | Checking of electrical resistance  | 0 to 1000 Ω<br>Compliant /<br>noncompliant  |
| 334 | GOST R 55187 §9.14 |  |              |             | Measurement of creepage distance on  | Compliant /   |

| 1   | 2  | 3   | 4                            | 5           | 6  | 7  |
|-----|--|---|------------------------------|-------------|--|--|
|     |  |   |                              |             | surface of external insulation performs according to GOST 9920   | noncompliant   |
| 335 | GOST R 55187 §9.17                               |   |                              |             | Temperature rise tests with rated current:<br>- current<br>- temperature rise  | Passed/ failed<br>(0 to 20 kA):<br>(0 to 300 °C)                             |
| 336 | GOST R 55187 §9.18                               |   |                              |             | Short-time withstand tests of bushings:<br>- electrodynamic withstand current<br>- thermal withstand current                         | Passed / failed<br><br>(0,1 to 320 kA)<br>(0,1 to 120 kA)                    |
| 337 | GOST R 52034 §7.5.1                              | Insulators ceramic support for voltage above 1000 V                       | 23.43.10.110                 | 8546 209900 | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass  | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg                 |
| 338 | GOST R 52082 §§8.8.1; 8.8.4; 8.8.5; 8.9.2; 8.9.3 | Insulators polymer support for outdoor installations for voltage 6-220 kV | 23.43.10.110                 | 8546 209900 | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass  | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg                 |
| 339 | GOST R 52082 §8.4                                |   |                              |             | Test for дугоwithstand<br>- current  |  |
| 340 | GOST 22229 § 1.15                                | Ceramic bushing insulators for voltage above 1000 V                       | 23.43.10.110                 | 8546 209900 | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- measurement of resistance                         | Passed / failed<br>10 to 20 000 A<br>1 to 300 °C<br>1 μΩ to 2000 Ω           |
| 341 | GOST 22229 §1.16                                 |   |                              |             | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- resistance of safety conductor |  |
| 342 | GOST 1232 § 8.5                                  | Line pin porcelain and glass insulators for voltage 1 to 35 kV            | 23.43.10.110<br>23.19.25.000 | 8546 209900 | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass<br>- creepage distance                       | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 to 5000 mm |
| 343 | GOST 6490 §7.3.2                                 | Line suspended plate  | 23.43.10.110                 | 8546 209900 | Checking of construction. Mass. Mark-  | Compliant/   |

| 1   | 2   | 3  | 4                            | 5           | 6  | 7  |
|-----|---|--|------------------------------|-------------|--|--|
|     |   | insulators   | 23.19.25.000                 |             | ing. Montage.<br>- geometrical dimensions<br>- mass<br>- creepage distance                                     | noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 to 5000 mm               |
| 344 | GOST 12670 §§6.16; 6.20                           | Porcelain plate insulators   | 23.43.10.110<br>23.19.25.000 | 8546 209900 | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass<br>- creepage distance | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 to 5000 mm |
| 345 | GOST 28856 §5.4                                   | Line suspended rod polymer insulators  | 23.43.10.110<br>23.19.25.000 | 8546 209900 | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass<br>- creepage distance | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 to 5000 mm |
| 346 | GOST R 55189 §§8.6.1-8.6.4                        | Line suspended rod polymer insulators  |                              |             | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass<br>- creepage distance | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 to 5000 mm |
| 347 | GOST 433 §§4.2.1; 4.6                             | Power cables with rubber insulation  | 27.32.13.110                 | 8544        | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass<br>- creepage distance | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 to 5000 mm |
| 348 | GOST R 53769 §§8.2.1;8.8;<br>8.8.1; 8.8.2         | Power cables with plastic insulation for rated voltage 0,66; 1 and 3 kV                | 27.32.13.110                 | 8544        | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass<br>- creepage distance | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 to 5000 mm |
| 349 | GOST R 53769 §§8.3.2.1; 8.3.4                     |  |                              |             | Insulation resistance.<br>Power-frequency voltage test   | Compliant/<br>noncompliant<br>1 κΩ to 70 GΩ<br>0,5 to 5 κΩ                   |
| 350 | GOST 31947 §§8.2.1; 8.2.2;<br>8.3.4; 8.8.1; 8.8.2 | Wires and cables for electrical installations for rated voltage to 450/750 V including | 27.32.13.110                 | 8544        | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass<br>- creepage distance | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 to 5000 mm |



| 1   | 2                                | 3  | 4            | 5    | 6  | 7  |
|-----|----------------------------------|--|--------------|------|--|--|
| 351 | GOST 31947 §§8.3.1; 8.3.2; 8.3.4 |  |              |      | Insulation resistance.<br>Power-frequency voltage test   | Compliant/<br>noncompliant<br>1 kΩ to 70 GΩ<br>0,5 to 5 kΩ                   |
| 352 | GOST 18410 §§4.2.1; 4.9          | Power cables with impregnated paper insulation                 | 27.32.13.110 | 8544 | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass<br>- creepage distance         | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 to 5000 mm |
| 353 | GOST 18410 §4.3.1                |  |              |      | Measurement of electrical resistance to DC current   | Compliant/<br>noncompliant<br>1 μΩ to 2000 Ω                                 |
| 354 | GOST 18410 §§4.3.2; 4.3.3        |  |              |      | Insulation resistance.<br>Power-frequency voltage test   | Compliant/<br>noncompliant<br>1 kΩ to 70 GΩ<br>0,5 to 5 kΩ                   |
| 355 | GOST 16442 §§5.2.1; 5.6; 5.9     | Power cables with plastic insulation to 6 kV                   | 27.32        | 8544 | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass<br>- creepage distance         | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 to 5000 mm |
| 356 | GOST 16442 §§5.3.2; 5.3.3        |  |              |      | Insulation resistance.<br>Power-frequency voltage test   | Compliant/<br>noncompliant<br>1 kΩ to 70 GΩ<br>0,5 to 5 kΩ                   |
| 357 | GOST 16442 §5.3.1, 5.3.2         |  |              |      | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- measurement of resistance           | Passed / failed<br>1 to 20 000 A<br>1 to 300°<br>1 μΩ to 2000 Ω              |
| 358 | GOST 16441 §5.3                  | Oil-filled cables for AC voltage 110-500 kV                    | 27.32.13     | 8544 | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- mass<br>- creepage distance         | Compliant/<br>noncompliant<br>1 to 5000 mm<br>1 to 10 000 kg<br>1 to 5000 mm |
| 359 | GOST 31996 §10.10                | Power cables with plastic insulation for rated voltage to 3 kV | 27.32.13     | 8544 | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- temperature rise | Passed / failed<br>0,1 to 320 kA;<br>0,1 to 120 kA;<br>1 to 300              |
| 360 | GOST R 55025 §8.3.1;             | Power cables with plastic                                      | 27.32.14     | 8544 | Measurement of electrical resistance to  | Compliant/   |

| 1   | 2                                      | 3  | 4        | 5    | 6  | 7   |
|-----|--|--|----------|------|--|---|
|     |  | insulation for rated voltage 6 to 35 kV including  |          |      | DC current   | noncompliant<br>1 $\mu\Omega$ to 2000 $\Omega$  |
| 361 | GOST R 53769 §8.3.1;                   | Power cables with plastic insulation for rated voltage 0,66; 1 and 3 kV                                | 27.32.14 | 8544 | Measurement of electrical resistance to DC current   | Compliant/<br>noncompliant<br>1 $\mu\Omega$ to 2000 $\Omega$  |
| 362 | GOST R IEC 60840 §§ 8.5, 10.5, Annex A | Power cables with extruded insulation and fittings to them for rated voltage above 30 kV up to 150 kV  | 27.32.14 | 8544 | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- measurement of resistance                                 | Passed / failed<br>1 to 20 000 A<br>1 to 300 <sup>0</sup> C<br>1 $\mu\Omega$ to 2000 $\Omega$             |
| 363 | GOST R IEC 60840 Annex A               |  |          |      | Short-time withstand tests:<br>- electrodynamic withstand current to 320 kA;<br>- thermal withstand current to 120 kA;<br>- temperature rise | Passed / failed<br><br>Passed / failed<br>1 to 300 <sup>0</sup> C   |
| 364 | GOST R IEC 62067 §10.5, Annex A        | Power cables with extruded insulation and fittings to them for rated voltage above 150 kV up to 500 kV | 27.32.14 | 8544 | Temperature rise tests with rated current:<br>- current<br>- temperature rise<br>- measurement of resistance                                 | Compliant/<br>noncompliant<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C<br>1 $\mu\Omega$ to 2000 $\Omega$ |
| 365 | GOST R IEC 62067 Annex A               |  |          |      | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- temperature rise                       | Passed / failed<br>0,1 to 320 kA;<br>0,1 to 120 kA;<br>1 to 300 <sup>0</sup> C                            |
| 366 | GOST 24334 §5.3.2                      | Power cables for non-stationary laying   | 27.32.13 | 8544 | Requirements to temperature rise:<br>- current<br>- temperature rise<br>Measurement of electrical resistance to DC current                   | Passed / failed<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C<br>1 $\mu\Omega$ to 2000 $\Omega$            |
| 367 | GOST 23981 §§5.1, 5.2                  | Cable tips   | 27.32.13 | 8544 | Checking of construction. Mass. Marking. Montage.<br>- geometrical dimensions<br>- Checking of marking                                       | Compliant/<br>noncompliant<br>1 to 5000 mm  |
| 368 | GOST 23981 §§5.6                       |  |          |      | Temperature rise tests with rated current:<br><br>- current<br>- temperature rise  | Compliant/<br>noncompliant<br>10 to 20 000 A<br>1 to 300 <sup>0</sup> C                                   |

| 1   | 2                                     | 3   | 4                       | 5                                     | 6   | 7  |
|-----|---------------------------------------|---|-------------------------|---------------------------------------|---|--|
|     |                                       |   |                         |                                       | - measurement of resistance   | 1 $\mu\Omega$ to 2000 $\Omega$   |
| 369 | STO 56947007-29.060.50.015-2008 §11.7 | Lightning protection cable with built-in optical cable, lightning protection cable  | 27.31.12.120            | 8544<br>8544 70 000                   | Short-time withstand tests:<br>- electrodynamic withstand current<br>- thermal withstand current<br>- temperature rise  | Passed / failed<br>0,1 to 320 kA;<br>0,1 to 120 kA;<br>1 to to 300 <sup>0</sup> C      |
| 370 | STO 56947007-29.060.50.015-2008 §11.8 |   |                         |                                       | Withstand to DC component of lightning current  | Passed / failed<br>1 to 300 Q  |
| 371 | GOST 13781.0 Section 6                | Couplings for power cables for voltage to 35 kV including                           | 27.90.33.110            | 8544                                  | Requirements to temperature rise<br>- temperature rise  | Passed / failed<br>1 to 300 <sup>0</sup> C   |
| 372 | GOST 13781.0 §6.11                    |   |                         |                                       | Short-time withstand tests:<br><br>- electrodynamic withstand current<br>- thermal withstand current<br>- temperature rise  | Passed / failed<br><br>0,1 to 320 kA;<br>0,1 to 120 kA;<br>1 to to 300 <sup>0</sup> C  |
| 373 | GOST R 52266 §7.6.1; 7.6.3, 7.6.2     | Optical cables  | 27.31.12.120            | 8544 70 000                           | Checking of construction and constructive dimensions.<br>Checking of geometric dimensions<br>Checking of serviceability of OF.<br><br>Checking of absence of breaks conductors and contacts between them. | Compliant/<br>noncompliant<br>Compliant/<br>noncompliant<br>Compliant/<br>noncompliant |
| 374 | GOST R 52266 §7.3.                    |   |                         |                                       | Measurement of damping factor   | Compliant/<br>noncompliant<br>0,05 dB/dB   |
| 375 | GOST R 52266 §7.8.1; §7.8.3; §7.8.4   |   |                         |                                       | Electrical resistance of protective hose.<br>Electrical Insulation resistance of current-carrying conductors.<br>Measurement of electrical resistance of conductors to DC current                         | Compliant/<br>noncompliant<br>1 $\mu\Omega$ to 2000 $\Omega$                           |
| 376 | GOST R 12.4.234 §6.18                 | Materials and special clothing for protection against thermal risks of electric arc | 13.10<br>13.20<br>13.91 | 5208, 5209,<br>5210, 5211,<br>551513, | Withstand to thermal exposure of electric arc   | 1 to 100 cal/sm <sup>2</sup><br>Passed / failed  |

| 1   | 2  | 3   | 4  | 5  | 6   | 7   |
|-----|--|---|--|--|---|---|
| 377 | GOST 3811                                    |   | 13.92<br>13.95<br>13.96<br>13.99<br><br>14.12<br>14.13<br>14.14<br>14.39 | 551522,<br>55162400,<br>5512, 5513,<br>5514, 5515,<br>5516, 6201,<br>62011390,<br>62021390,<br>62032911,<br>62032210,<br>62032280,<br>62032310,<br>62042310,<br>621149, 621139 | Definition of surface density of materials (calculated)   | -   |
| 378 | GOST R 54827 Section 25                      | Power transformers  | 27.11.4  | 8504 210000<br>8504 220000<br>8504 230000  | Short-time withstand tests and current striking shocks.<br>0,1 to 208 kV  | Irms 0,1 to 70 kA<br>Idyn 0,1 to 180 kA<br>0,1 to 4 s<br>Compliant/<br>noncompliant |
| 379 | GOST R 52565 § 9.2.6                         | AC current circuit-breakers for voltage 3 to 750 kV;<br>Sealed bushings | 27.12.10.110   | 8535 210000<br>8535 290000   | Mechanical performance tests with the combined action of wire tension and wind load:<br>0 to 10000 N              | Compliant/<br>noncompliant  |
| 380 | GOST R 52726 § 8.5.6                         | AC current disconnectors and earthing switches for voltage above 1 kV   | 27.12.10.120   | 8535 300000  | Operation with application of rated static mechanical load to terminals:<br>0 to 10000 N                          | Compliant/<br>noncompliant  |
| 381 | GOST R 52725 § 8.2                           | Surge arresters with spark gaps;<br>Non-linear surge arresters          | 27.12.10.130   | 8535 400000  | Tests of compliance to safety requirements:<br>0 to 1 Ω;<br>0 to 300 mm   | Compliant/<br>noncompliant  |
| 382 | GOST IEC 61439-6 § 10.2.3.1, 10.2.102, 10.10 | Magistral and distributive busducts                                     | 27.32.13.199   | 8544   | Requirements to temperature rise tests and overload currents:<br>up to 12 kA<br>up to 300 °C<br>up to 1000 cycles | Passed / failed   |
| 383 | GOST IEC 61439-6 § 10.5.2, 10.5.3, 10.11     | Magistral and distributive busducts                                     | 27.32.13.199   | 8544   | Requirements to short-time withstand tests:<br>Irms = 125 kA<br>Idyn = 320 kA                                     | Passed / failed   |
| 384 | GOST 10693-81 § 6.12                         | Sealed bushings   | 27.90.12.120   | 8546 900000  | Tests for mechanical wearing and canti-   | Compliant/  |

| 1   | 2                        | 3   | 4  | 5  | 6  | 7                           |
|-----|--------------------------|---|--|--|--|-----------------------------|
|     |                          |   |  |  | lever loads:<br>0 to 10000 N   | noncompliant                |
| 385 | GOST R 55187-2012 § 9.19 | Sealed bushings   | 27.90.12.120   | 8546 900000  | Tests for mechanical wearing and cantilever loads:<br>0 to 10000 N   | Compliant/<br>noncompliant  |
| 386 | GOST R ISO 6330          | Materials and special clothing for protection:<br>- against thermal risks of electric arc;<br>- against non-ionizing emissions;<br>- against shock of electric current;<br>- against exposures of static electricity;<br>- against mechanical exposures;<br>- against general industrial pollutions;<br>- against heat and flame;<br>- against high temperatures, low temperatures and heat emissions;<br>- others. | 13.2<br>13.9<br>14.12<br>14.13<br>14.14<br>14.19<br>14.3<br>14.31<br>14.39 | 5208; 5209<br>5210; 5211<br>5515130000<br>5515220000<br>5516240000<br>5512; 5513<br>5514; 5515<br>5516; 6201<br>6201139000<br>6202139000<br>6203291100<br>6203221000<br>6203228000<br>6203231000<br>6204231000<br>6211490000<br>6211390000 | Performing of washing and drying:<br>up to 1000 cycles<br>up to 2 kg | Performed/<br>not performed |

Deputy General Director of Tests and Certification,  
Head of Testing Center  
Joint Stock Company «Research and Development Center  
at Federal Grid Company of Unified Energy System»

V.V. Boykov

Stamp